

VOC Content Test Certificate

Wednesday, August 21st, 2013

Manufacturer: Otaria Pty Ltd (PO Box 1934, Maroubra NSW 2035)

Sample Description: Efflock

Date Tested: August 2013 (Tested by FORAY Laboratories – NATA Accreditation 1231)

Test Method: SCAQMD Method 304-91 Determination of Volatile Organic Compounds (VOC) in Various Materials as referenced by South Coast Air Quality Management District (SCAQMD) Rule 1168

Test Data:

Specification	
Green Building Council of Australia Green Star Office Design V3 IEQ-13	Efflock
Interior Sealer 65 grams per Litre as VOC content per material	15 grams per Litre as VOC content per material

When used on concrete, the VOC result is expected to be less than the above test result. The ready to use concrete additive solution is made in a 1:100 ratio of concentrate (tested) to water.



Dr. Vyt Garnys
PhD, BSc(Hons) AIMM, ARACI, ISIAQ
ACA, AIRAH, FMA
Managing Director and Principal Consultant



Nick Joy
BSc(Hons)
Consultant

CV130817a