Executive Summary

Objective This report presents an appraisal of the fire resistance performance of a single-

leaf, timber sliding doorset referenced Evokit Fire E130.

Report Sponsor ERMETIKA S.R.L.

Address Via Trani, 126

76121 - BARLETTA (BT)

Italy

Summary of Conclusions

Valid until

It can be concluded that the proposed timber doorset, should provide at least 30 minutes integrity and insulation (I_1 and I_2) performance, if tested in

accordance with BS EN 1634-1: 2014.

This assessment represents our opinion as to the performance likely to be demonstrated, on the basis of the evidence referred to above. We express no opinion as to whether that evidence, and/or this assessment, would be regarded by any Building Control authority as sufficient for that or any other purpose. This assessment is provided to the client for its own purposes and we cannot opine on whether it will be accepted by Building Control authorities or any other third parties for any purpose.

8th May 2028

This report may only be reproduced in full. Extracts or abridgements of reports shall not be published without permission of Warringtonfire