

# CERTIFICATE OF CONFORMITY

**Certificate No.:** LC20759-1

**Date Issued:** February 9, 2022

**Project No.:** 20759

**Certification System: Type 3**  
(ISO / IEC 17067)

**Client No.:** LC1231751

**Applicant:** Victron Energy B.V.  
De Paal 35  
1351 JG Almere Haven  
Netherlands



*Kaavideh Shellen*

**Issued by:** \_\_\_\_\_  
**Certification Manager**

**Products:**

- Phoenix Inverter
- Models: MultiPlus II 12/3000/120-50 2x120V

<b>Model/Type(s):</b>	<b>MultiPlus-II 12-3000-120-50 2x120V</b>
Rating and main characteristics:	12-3000-120-50 2x120V
<b>INVERTER</b>	
Input voltage range (V DC)	9,5 – 17
Output	Output voltage: 120 VAC ± 2% Frequency: 60 Hz ± 0,1% (can be adjusted to 50Hz)
Cont. output power at 25°C (VA) (non linear load, crest factor 3:1)	3000
Cont. output power at 25°C (W)	2400
Cont. output power at 40°C (W)	2200
Cont. output power at 65°C (W)	1700
Peak power (W)	5500
<b>CHARGER</b>	
AC Input	Split phase: 180-280 VAC 45 – 65 Hz Single phase: 90-140 VAC 45 – 65 Hz
Charge voltage 'absorption' (V DC)	14,4
Charge voltage 'float' (V DC)	13,8
Storage mode (V DC)	13,2
Charge current house battery (A) (at 25°C ambient)	120

The 'C' and 'US' indicators adjacent to the LabTest Certification Mark shall signify that the product has been evaluated by an accredited laboratory to the applicable Canadian and US Standards. The subject area shall be displayed with the LabTest Certification Mark to identify the Standard Number, and Revision Level.

Applicant: Victron Energy B.V.

Certificate No.: LC20759-1

**Applicable requirements:**

- UL 458 6<sup>th</sup> Edition

**Conditions of acceptability:**

- None

**General Note:**

- Refer to LC Listing Report No. 10.00.20759-1\_Rev0



ISO 17020

ISO 17025

ISO 17065

The 'C' and 'US' indicators adjacent to the LabTest Certification Mark shall signify that the product has been evaluated by an accredited laboratory to the applicable Canadian and US Standards. The subject area shall be displayed with the LabTest Certification Mark to identify the Standard Number, and Revision Level.