


HEFEI SUNHOPE TRADE CO.,LTD  
C7-1507 YANDUN ROAD, HEFEI, CHINA

The following sample(s) was/were submitted and identified on behalf of the client as:

Sample Description : Woven fabric: polyester fluorescent light filter in blue  
Country of Destination : US  
Proposed Care Instruction : -  
Test Performed : Selected test(s) as requested by applicant  
Sample Receiving Date : Nov 22, 2017  
Testing Period : Nov 23, 2017 - Nov 29, 2017  
Test Result(s) : Unless otherwise stated the results shown in this test report refer only to the sample(s) tested. For further details, please refer to the following page(s).

Signed for and on behalf of  
SGS-CSTC Standards Technical Services (Shanghai) Co. Ltd



Hattie Chen  
Account Executive



Unless otherwise agreed in writing, this document is issued by the Company subject to its General Conditions of Service printed overleaf, available on request or accessible at <http://www.sgs.com/en/Terms-and-Conditions.aspx> and, for electronic format documents, subject to Terms and Conditions for Electronic Documents at <http://www.sgs.com/en/Terms-and-Conditions/Terms-e-Documents.aspx>. Attention is drawn to the limitation of liability, indemnification and jurisdiction issues defined therein. Any holder of this document is advised that information contained hereon reflects the Company's findings at the time of its intervention only and within the limits of Client's instructions, if any. The Company's sole responsibility is to its Client and this document does not exonerate parties to a transaction from exercising all their rights and obligations under the transaction documents. This document cannot be reproduced except in full, without prior written approval of the Company. Any unauthorized alteration, forgery or falsification of the content or appearance of this document is unlawful and offenders may be prosecuted to the fullest extent of the law. Unless otherwise stated the results shown in this test report refer only to the sample(s) tested and such sample(s) are retained for 30 days only.  
Attention: To check the authenticity of testing /inspection report & certificate, please contact us at telephone: (86-755) 8307 1443, or email: [CN.Doccheck@sgs.com](mailto:CN.Doccheck@sgs.com)

**Test Result**

**Fire Tests for Flame Propagation of Textiles and Films**

(NFPA 701-2015; Method 1)

As Received

Specimen	1	2	3	4	5	6	7	8	9	10	Average
Afterflame time(s)	NIL	NIL	NIL	NIL	NIL	NIL	NIL	NIL	NIL	NIL	NIL
The burning time of material that falls to the bottom of the chamber(s)	NIL	NIL	NIL	NIL	NIL	NIL	NIL	NIL	NIL	NIL	NIL
The dripping of molten material	Y	Y	Y	Y	Y	Y	Y	Y	Y	Y	
Specimen	Weight (g)		Weight Loss (%)								
	Original (O)		After test (T)		(O-T)/O X 100						
1	5.2		3.7		28.8						
2	5.2		4.0		23.1						
3	5.2		4.1		21.2						
4	5.2		3.7		28.8						
5	5.3		3.8		28.3						
6	5.2		3.9		25.0						
7	5.3		4.0		24.5						
8	5.2		3.9		25.0						
9	5.2		3.8		26.9						
10	5.2		3.9		25.0						
Average				25.7							
Standards deviation				2.5							

**Remark:** Y: Yes N: No

**Conditioning:**

- The specimens were dried for at least 30 minutes at 105 °C ± 3 °C (220 °F ± 5 °F).

**Requirements:**

Fragments or residues of specimens that fall to the floor of the test chamber shall not continue to burn for more than an average of 2 seconds per specimen for the sample of 10 specimens.

The average weight loss of the 10 specimens in a sample shall be 40 percent or less.

No individual specimen's percent mass loss shall deviate more than 3 standard deviations from the mean for the 10 specimens.

When a retest is required, no individual specimen's percent mass loss in the second set of specimens shall deviate from the mean value by more than 3 standard deviations calculated for the second set.

**Comment:**

The submitted sample **meets** the requirement prescribed in Chapter 10 of NFPA 701-2015 in "As Received" states.

\*\*\* End of Report \*\*\*

