Resetting Your RAD-0002-ZR Oxygen Deficiency Safety Alarm



On the main unit in the bottom right-hand corner is a small hole with a white arrow circling it. Behind this hole is a soft, rubberized button.



Use the head of a pen to gently depress and release the recessed button. This will initiate a full device reset, including a brief countdown and activation of all visual and audible indicators.