## Reflectatherm Plus

REFLECTIVE VAPOUR CONTROL LAYER

Reflectatherm Plus is a reflective, high resistance air and vapour control layer for PHYSICAL PROPERTIES internal walls, ceilings and floors, specifically designed to enhance the thermal performance when placed on the warm side of the insulation.

The membrane should be installed with the foil side facing the cavity. In ceilings the product is placed between the underside of the rafters and the ceiling lining. Adjacent sheets should be lapped by at least 50mm and sealed with a suitable tape. Minimise penetrations caused by services and seal all joints.

## **Key Benefits**

- R value of 0.78 m<sup>2</sup>K/W when used with a minimum 19mm service cavity.
- High vapour resistance.
- Improved airtightness.
- Creates service void.
- Creates an unbroken vapour control layer.
- Sd Value of 150m.
- Vapour Resistance 750 MNs/g.
- Help meets the requirements of the Part L in England and Wales, Section 6 in Scotland, and Technical Guidance Document L in Ireland.



| Property   | Test<br>Method   | Mean Results                                      |              |  |  |  |  |  |  |
|--|------------------|---|--------------|--|--|--|--|--|--|
| Roll Size - Standard<br>Roll Size - with integrated tape | n/a              | 1.5m × 50m, 2.7m × 100m & 3m × 100m<br>1.5m × 50m |              |  |  |  |  |  |  |
| Base Membrane  |                  |   |              |  |  |  |  |  |  |
| Mass per unit area                                       | EN 1849-2        | 150g/m²   |              |  |  |  |  |  |  |
| Reaction to Fire   | EN 11925-2       | Class E*  |              |  |  |  |  |  |  |
| Water vapour resistance Sd                               | EN 1931          | 150m  |              |  |  |  |  |  |  |
| Vapour resistance  | EN 1931          |   |              |  |  |  |  |  |  |
| Water penetration  | EN 1928          | Class W1 (Before and After ageing)                |              |  |  |  |  |  |  |
| Tensile strength   | EN 12311-2       | MD 255N/50mm                                      | CD 200N/50mm |  |  |  |  |  |  |
| Elongation   | EN 12311-1       | MD 59%  | CD 70%       |  |  |  |  |  |  |
| Tear resistance  | EN 12310-1       | MD 164N   | CD 157N      |  |  |  |  |  |  |
| Flexibility at low temperature                           | EN 1109          | No cracking at temperature minus 40°C             |              |  |  |  |  |  |  |
| Emissivity   | BS EN 15976:2011 | 0.04  |              |  |  |  |  |  |  |

\*When tested to EN 11925-2 over a rock wool substrate

## U Value - Performance Ready Reckoner

| Stud  | 89mm  |       |       |       |        | 95mm  |       |       |       | 115mm  |       |       |       |       | I 40mm |       |       |       |       |        | 145mm |       |       |       |        |
|---|-------|-------|-------|-------|--------|-------|-------|-------|-------|--------|-------|-------|-------|-------|--------|-------|-------|-------|-------|--------|-------|-------|-------|-------|--------|
| Insulation<br>k Value                           | 0.040 | 0.037 | 0.035 | 0.032 | 0.022* | 0.040 | 0.037 | 0.035 | 0.032 | 0.022* | 0.040 | 0.037 | 0.035 | 0.032 | 0.022* | 0.040 | 0.037 | 0.035 | 0.032 | 0.022* | 0.040 | 0.037 | 0.035 | 0.032 | 0.022* |
| Reflectashield TF                               | 0.31  | 0.30  | 0.30  | 0.29  | 0.24   | 0.30  | 0.29  | 0.29  | 0.28  | 0.24   | 0.27  | 0.26  | 0.26  | 0.25  | 0.21   | 0.24  | 0.23  | 0.23  | 0.22  | 0.19   | 0.24  | 0.23  | 0.22  | 0.21  | 0.18   |
| Reflectatherm<br>Plus                           | 0.33  | 0.32  | 0.31  | 0.30  | 0.25   | 0.32  | 0.31  | 0.30  | 0.29  | 0.24   | 0.28  | 0.27  | 0.27  | 0.23  | 0.21   | 0.25  | 0.24  | 0.23  | 0.22  | 0.19   | 0.24  | 0.23  | 0.23  | 0.22  | 0.18   |
| Reflectashield<br>TF &<br>Reflectatherm<br>Plus | 0.27  | 0.26  | 0.26  | 0.25  | 0.22   | 0.26  | 0.26  | 0.24  | 0.24  | 0.21   | 0.24  | 0.23  | 0.23  | 0.22  | 0.19   | 0.21  | 0.21  | 0.20  | 0.19  | 0.16   | 0.21  | 0.20  | 0.20  | 0.19  | 0.16   |



st When utilising rigid insulation boards between studs, accommodation for services should be considered. The above calculations are based on fully filling the stud with insulation and the provision of a service cavity.





