

LABORATORY ANALYSIS REPORT

DATE:	11-Jul-2007	PAGE:	2 Of 8
CLIENT:	Harmsco Filtration Products 7169 North 49 th Terrace West Palm Beach, FL 33407	PROJECT NO.:	4740
CONTACT:	Ms. Cyndi Benson	REPORT NO.:	4740-CYS
		COLLECTED BY:	IBR
		PROJECT REC'D:	21-May-2007
		PRODUCT DESC:	Harmsco Drinking Water Filtration Systems (4 Types of Filters in Housings)

NSF/ANSI Standard 53 - 2007 Cyst (CYS) Reduction

Test Unit: 4740-2

<u>Sample Point</u>	<u>Particle Size</u> <u>Microns</u>	<u>Influent</u> <u>(Particles/mL)</u>	<u>Effluent</u> <u>(Particles/mL)</u>	<u>Percent</u> <u>Reduction</u>	<u>Pressure</u> <u>Drop</u> <u>(PSIG)</u>	<u>Flow Rate</u> <u>(GPM)</u>	<u>Volume</u> <u>Treated</u> <u>(Gallons)</u>
Flush/Condition	3	-	<1	-	5.5	15	-
8th Cycle	3	127,000	99	99.92	5.5	15	1,200
25% Reduction	3	113,000	57	99.95	5.3	11	2,180
50% Reduction	3	183,000	77	99.96	5.6	6.0	3,610
75% Reduction	3	135,000	73	99.95	5.5	3.0	4,790

Test Unit: 4740-6

<u>Sample Point</u>	<u>Particle Size</u> <u>Microns</u>	<u>Influent</u> <u>(Particles/mL)</u>	<u>Effluent</u> <u>(Particles/mL)</u>	<u>Percent</u> <u>Reduction</u>	<u>Pressure</u> <u>Drop</u> <u>(PSIG)</u>	<u>Flow Rate</u> <u>(GPM)</u>	<u>Volume</u> <u>Treated</u> <u>(Gallons)</u>
Flush/Condition	3	-	<1	-	4.8	15	-
8th Cycle	3	127,000	98	99.92	4.8	15	1,200
25% Reduction	3	113,000	44	99.96	4.7	11	2,190
50% Reduction	3	183,000	64	99.97	4.6	6.0	3,620
75% Reduction	3	135,000	55	99.96	4.5	3.0	4,780

General Water Characteristics

<u>Parameters</u>	<u>Specifications</u>	<u>Results</u>
pH	7.0 ± 0.5 su	7.7 su
Temperature	20 ± 2.5 °C	21 °C
Hardness	≤ 170 mg/L	160 mg/L
Total Dissolved Solids	200 - 500 mg/L	316 mg/L
Turbidity	<1 NTU	0.23 NTU

Note: Operating Cycle: 10 minutes on / 10 minutes off.
Contaminant: Polystyrene Latex Microspheres, (size = 3.00 ± 0.15 um)
Testing Date: 8-Jun-2007 to 12-Jun-2007

4740-2 = Harmsco Filtration Products drinking water filter PP-HC-40-1 in housing, received 21-May-2007.

4740-6 = Harmsco Filtration Products drinking water filter PP-HC-40-1 in housing, received 21-May-2007.



Pace Analytical Services, Inc.
1700 Elm Street, Suite 200
Minneapolis, MN 55414

Phone: 612.607.1700
Fax: 612.656.1181

LABORATORY ANALYSIS REPORT

DATE: 31-Mar-2009

PAGE: 1 Of 4

CLIENT: Harmsco Filtration Products
7169 N. 49th Terrace
West Palm Beach, FL 33407

PROJECT NO.: 5093-CYS Rev. 1
COLLECTED BY: IBR
DATE RECEIVED: 17-Feb-2009
PROJECT DESC: 2 Hurricane 40-HP housing with
PPFS-40-1 Cartridge

CONTACT: Ms. Cyndi Benson

Dear Ms. Benson:

Enclosed, please find our revised final laboratory report regarding the evaluation of **2 Hurricane 40-HP filter housings with PPFS-40-1 cartridges for Cyst Reduction (CYS)** (See revision notes on **page 4**). Two systems were tested simultaneously referencing protocol published in NSF/ANSI Standard 53-2007a, with the exception of allowing the backpressure to monitor the pressure drop across the system as the flow rate decreased to 75% reduction.

Pace Analytical Services, Inc. appreciates the opportunity to provide you with this product testing service. If you have any questions or comments, please feel free to call me at 612.656.1102; fax 612.656.1181, or email tim.shannon@pacelabs.com.

Sincerely,

Tim Shannon
Project Manager

LABORATORY ANALYSIS REPORT

DATE: 31-Mar-2009 **PAGE:** 2 Of 4

CLIENT: Harmsco Filtration Products **PROJECT NO.:** 5093-CYS Rev. 1
7169 N. 49th Terrace **COLLECTED BY:** IBR
West Palm Beach, FL 33407 **DATE RECEIVED:** 17-Feb-2009
PROJECT DESC: 2 Hurricane 40-HP housing with
PPFS-40-1 Cartridge

CONTACT: Ms. Cyndi Benson

NSF/ANSI Standard 53 – 2007a Cyst (CYS) Reduction

Test Unit 5093-3

Sample Point	System Pressure (psi)	Differential Pressure (psid)	Influent (Particles/L)	Effluent (Particles/mL)	Percent Reduction	Flow Rate (GPM)	Volume Treated (Gallons)
Flush	56.7	13.8	-	0	-	15	-
8 th Cycle	57.1	12.6	87000	6	99.999	15	1050
25% Flow Red.	64.2	39.7	149500	165	99.890	11	6000
50% Flow Red.	67.2	52.6	103500	130	99.874	8	7425
75% Flow Red.	69.6	63.3	172500	699	99.595	4	9425

Test Unit 5093-4

Sample Point	System Pressure (psi)	Differential Pressure (psid)	Influent (Particles/mL)	Effluent (Particles/mL)	Percent Reduction	Flow Rate (GPM)	Volume Treated (Gallons)
Flush	56.7	14.8	-	0	-	15	-
8 th Cycle	57.1	13.5	87000	4	>99.999	15	1050
25% Flow Red.	64.2	40.9	149500	81	99.946	11	6030
50% Flow Red.	67.2	53.6	103500	69	99.933	8	7455
75% Flow Red.	69.6	64.1	172500	1013	99.413	4	9455

Note: Operating Cycle: 10 minutes on / 10 minutes off.
Contaminant: Polystyrene Latex Microspheres, (size = 3.00um) and 0-5 micron test dust for loading.
Test Date: 9-Mar-2009 – 16-Mar-2009
Neither pressure drop nor flow rate was adjusted during the test.



LABORATORY ANALYSIS REPORT

DATE: 31-Mar-2009 **PAGE:** 3 Of 4
CLIENT: Harmsco Filtration Products **PROJECT NO.:** 5093-CYS Rev. 1
7169 N. 49th Terrace **COLLECTED BY:** IBR
West Palm Beach, FL 33407 **DATE RECEIVED:** 17-Feb-2009
PROJECT DESC: 2 Hurricane 40-HP housing with
PPFS-40-1 Cartridge
CONTACT: Ms. Cyndi Benson

General Test Water Characteristics

<u>Parameters</u>	<u>Specifications</u>	<u>Results</u>
pH	7.5 ± 0.5 su	7.6 su
Temperature	20 ± 2.5 °C	18.9 °C
Total Dissolved Solids	200-500 mg/L	304 mg/L
Hardness	<170 mg/L	80 mg/L
Turbidity	<1 NTU	0.13 NTU

u = standard units

UV = Unit Volumes

GPM = Gallons Per Minute

NTU = Nephelometric Turbidity Unit

mg/L = Milligrams Per Liter, or Parts Per Million (ppm)

Cyst Reduction was subcontracted to Interbasic Resources in Grass Lake, MI.

Bubble Point Test per ASTM F316-03

Test Unit 5093-3

First bubble net Pressure: 43psi*

Test Unit 5093-4

First bubble net pressure: 45psi*

Note: Test Fluid: Water (Approximately 69 dynes/cm²)

Temperature: Ambient

Test Date: 17-Mar-2009

*Samples bubbled from filter media only. No bubbles from the seals or endcaps



Pace Analytical Services, Inc.
1700 Elm Street, Suite 200
Minneapolis, MN 55414

Phone: 612.607.1700
Fax: 612.656.1181

LABORATORY ANALYSIS REPORT

DATE: 31-Mar-2009

PAGE: 4 Of 4

CLIENT: Harmsco Filtration Products
7169 N. 49th Terrace
West Palm Beach, FL 33407

PROJECT NO.: 5093-CYS Rev. 1
COLLECTED BY: IBR
DATE RECEIVED: 17-Feb-2009
PROJECT DESC: 2 Hurricane 40-HP housing with
PPFS-40-1 Cartridge

CONTACT: Ms. Cyndi Benson

Revision 1

The 75% flow reduction point data for Test Unit 5093-4 was revised to add the system pressure of 69.6 psi and move the remaining numbers one column to the right.

This report has been reviewed for technical accuracy and completeness. The analyses were performed using EPA or other approved methodologies and the results were reported on an "as received" basis unless otherwise noted. These results relate only to the items tested.

END OF DOCUMENT



HARMSCO® FILTRATION PRODUCTS

P.O. BOX 14066, North Palm Beach, FL 33408(561) 848-9628

Toll Free 1(800) 327-3248


To Send a PO (561) 845-2474

E-Mail cbenson@harmsco.com

Turbidity for the PPF5-170-1 Cartridge
Tested in the HUR-170-HP Housing
Cartridge #1

Tested Using Arizona Fine Test Dust

Flow Rate GPM	Influent NTU	Effluent NTU	ΔP PSI
50	7	0.43	5
45	4.5	0.42	6
38.5	4.2	0.31	7
35	9	0.88	10
30	4.09	0.34	12
24	3.88	0.68	15
20	8.19	0.71	17
18	3.59	0.36	19
15	6.35	0.51	21
13	7.14	0.39	27



Turbidity for the PPFS-170-1 Cartridge
Tested in the HUR-170-HP Housing
Cartridge #2

Flow Rate GPM	Influent NTU	Effluent NTU	Δ P PSI
50	9.27	1.19	5
45	4.34	0.42	6
40	7.15	0.41	6
38.5	4.55	0.46	8
35	5.54	0.69	10
28	17.4	1.08	13
25	3.04	0.68	15
23	3.42	0.3	16
20	3.8	0.56	18
18.5	10.5	0.93	20
15	4	0.3	23
12.5	5.11	0.43	26

