

# GMA Certification Group

BUILDING SURVEYORS

ACN 150 435 617

*Leaders in Building Certification Services*

**GOLD COAST**

P: 07 5578 1622 E: [admin@gmacert.com.au](mailto:admin@gmacert.com.au)

Suite 26 "Advance Business Centre" 39-47 Lawrence Drive, Nerang  
P.O. Box 2760, Nerang Qld 4211



Our Ref: 20214183

INAPOD Pty Ltd

By Email: [justinb@officeportfolio.com.au](mailto:justinb@officeportfolio.com.au)

Att: Justin Brown

Dear Justin

RE INAPOD Office Pod Series

We have reviewed the literature provided in relation to the INAPOD Office Pod series (S,W,D,C,M) and it is our opinion that the units constitute "furniture" or a "joinery unit" and as such are not subject to the requirements of Clause C1:10 of the National Construction Code (NCC) Volume 1.

It is further our opinion that the installation of the INAPOD Office Pod series units into a building would not constitute building work that requires approval.

Like any loose furniture installation, placement of the units should consider the impacts on paths of travel to exits and maintaining clear exits widths of 1m.

Yours faithfully

G.R Mitchell Cdec, MBOINZ, FRICS, LFAIBS

Director

Building Surveyor Level 1 QLD - A20976

Building Certifier (Unrestricted) NT – 166064BU

Building Surveyor (Unlimited) VIC – BS-U 60810

Building Surveyor Practitioner Level 1 – WA – BSP2298

Building Surveyor – Unrestricted – NSW – BDC3039

22 November 2021

[www.gmacert.com.au](http://www.gmacert.com.au)

BUILDING APPROVALS & INSPECTIONS

BUILDING CERTIFICATION

ENERGY EFFICIENCY ASSESSMENTS

TOWN PLANNING

Gold Coast

Caboolture

Townsville

Cairns

Port Douglas

Childers

Kingscliff



Liability Limited By a Scheme Approved Under Professional Standards Legislation

Member Australian Institute of Building Surveyors Professional Standards Scheme