

2820 S. English Station Road - Louisville, KY 40299  
 Tel: (502) 357-0132 Fax (502) 267-8379


**TEST NO. 21-433-2**


## ISO 16890:2016 Air Filter Test Result Summary

Sections 2, and 4


page 1 of 3

<b>Counter Information</b>	Manufacturer: <u>TSI, Inc.</u>	<b>Test Conditions</b>	Test Flow Rate (FPM): <u>14.3 FPM / 7.25 cm/s</u>
	Model No.: <u>3330</u>		Test Aerosol: <u>Aerosolized KCl &amp; DEHS</u>
	Serial Number: <u>3330115003</u>		Temperature (Deg F): <u>76.0</u>
	IPA Discharge Method: <input checked="" type="checkbox"/> Vapor Treated <input type="checkbox"/> IPA Dip Method		Relative Humidity (%): <u>48.2</u>
			Barometer (in Hg): <u>29.45</u>

<b>Device Tested</b>	Manufacturer: <u>Good Air Teams LLC</u>	
	Model: <u>Flat Sheet Media</u>	
	Part Number: <u>K9-Mask Clean Breathe</u>	
	Dimensions: <u>12.5" X 5.5"</u>	
	Type of Media: <u>PP Lattice/PP Spunbond/Carbon</u>	
	Media Area: <u>Tested : 0.145 ft<sup>2</sup></u>	
	Construction: <u>Flat Sheet Media</u>	
	Filter/Media Electrostatic Charge: <u>NA</u>	
	Media Color: <u>Grey / Black</u>	
	Media Adhesive: <u>NA</u>	
	Sample Procurement: <u>Good Air Teams LLC</u>	
	Initial Filter Weight (g): <u>NA</u>	
Final Device Weight (g): <u>NA</u>		
Initial Pressure Drop ("w.c.): <u>0.02</u>		



DEHS Size .03 - 1.0 and KCL Size 1.0 - 10.0					
Range (µm)	Geo. Mean	Initial Efficiency (%)	Discharged Efficiency (%)	Upstream Number of Particles per Test	
				Pre	Post
0.3-0.4	0.35	1	2	438479	680236
0.4-0.55	0.47	2	2	228927	371979
0.55-0.7	0.62	2	3	95805	164151
0.7-1.0	0.84	3	3	147861	260290
1.0-1.3	1.14	4	3	44083	79129
1.3-1.6	1.44	5	5	35137	63334
1.6-2.0	1.88	7	7	74816	135964
2.0-3.0	2.57	12	12	56370	100469
3.0-4.0	3.46	23	22	32665	55243
4.0-5.5	4.69	41	40	16043	26279
5.5-7.0	6.20	61	59	2900	4409
7.0-10.0	8.37	74	69	2293	3200




Reporting Data			
	ePM <sub>1</sub>	ePM <sub>2,5</sub>	ePM <sub>10</sub>
<b>Minimum</b>	<b>2%</b>	<b>4%</b>	<b>--</b>
<b>Average</b>	<b>2%</b>	<b>4%</b>	<b>30%</b>
<b>Reported</b>	<b>N/A*</b>	<b>N/A*</b>	<b>N/A*</b>

\* Any Reporting value of N/A shows the minimum efficiency is below 50% for that ePM

%	Airflow	Δp Initial	Δp Post IPA
	(CFM)	(in WG)	(in WG)
25	3.6	0.005	0.005
50	7.2	0.010	0.010
75	10.7	0.015	0.015
100	14.3	0.020	0.020
125	17.9	0.025	0.025

ISO 16890-1										
Data Entry Table							Reporting Data			
DEHS								ePM <sub>1</sub>	ePM <sub>2,5</sub>	ePM <sub>10</sub>
d <sub>i</sub>	d <sub>i+1</sub>	d <sub>m</sub>	Δln d <sub>i</sub>	E <sub>i</sub>	E <sub>D,i</sub>	E <sub>A,i</sub>	Minimum	2%	4%	--
0.30	0.40	0.35	0.29	1.2%	2.1%	1.7%	Average	2%	4%	30%
0.40	0.55	0.47	0.32	1.5%	2.4%	2.0%	Reported	N/A*	N/A*	N/A*
0.55	0.70	0.62	0.24	1.9%	2.9%	2.4%	* Any Reporting value of N/A shows the minimum efficiency is below 50% for that ePM value			
0.70	1.00	0.84	0.36	2.6%	2.6%	2.6%				
KCL										
1.00	1.30	1.14	0.26	3.5%	3.1%	3.3%				
1.30	1.60	1.44	0.21	5.4%	5.4%	5.4%				
1.60	2.20	1.88	0.32	7.0%	7.0%	7.0%				
2.20	3.00	2.57	0.31	12.3%	11.9%	12.1%				
3.00	4.00	3.46	0.29	22.8%	21.5%	22.2%				
4.00	5.50	4.69	0.32	41.4%	39.6%	40.5%				
5.50	7.00	6.20	0.24	61.4%	58.5%	60.0%				
7.00	10.00	8.37	0.36	73.6%	68.8%	71.2%				
ePM <sub>1</sub> Calculations										
d <sub>i</sub>	d <sub>i+1</sub>	d <sub>m</sub>	Δln d <sub>i</sub>	E <sub>A,i</sub>	q <sub>3σ</sub>	q <sub>3σ</sub> *Δln d <sub>i</sub>	E <sub>D,i</sub> *q <sub>3σ</sub> *Δln d <sub>i</sub>	E <sub>A,i</sub> *q <sub>3σ</sub> *Δln d <sub>i</sub>	E <sub>min</sub> (PM <sub>1</sub> )	E(PM <sub>1</sub> )
0.30	0.40	0.35	0.29	1.7%	22.627%	0.065095	0.001359	0.001077	2%	2%
0.40	0.55	0.47	0.32	2.0%	19.891%	0.063343	0.001532	0.001246		
0.55	0.70	0.62	0.24	2.4%	15.837%	0.038193	0.001122	0.000930		
0.70	1.00	0.84	0.36	2.6%	11.522%	0.041097	0.001082	0.001070		
Sums:					0.207728	0.005095	0.004324			
ePM <sub>2,5</sub> Calculations										
d <sub>i</sub>	d <sub>i+1</sub>	d <sub>m</sub>	Δln d <sub>i</sub>	E <sub>A,i</sub>	q <sub>3σ</sub>	q <sub>3σ</sub> *Δln d <sub>i</sub>	E <sub>D,i</sub> *q <sub>3σ</sub> *Δln d <sub>i</sub>	E <sub>A,i</sub> *q <sub>3σ</sub> *Δln d <sub>i</sub>	E <sub>min</sub> (PM <sub>2,5</sub> )	E(PM <sub>2,5</sub> )
0.30	0.40	0.35	0.29	1.7%	22.627%	0.065095	0.001359	0.001077	4%	4%
0.40	0.55	0.47	0.32	2.0%	19.891%	0.063343	0.001532	0.001246		
0.55	0.70	0.62	0.24	2.4%	15.837%	0.038193	0.001122	0.000930		
0.70	1.00	0.84	0.36	2.6%	11.522%	0.041097	0.001082	0.001070		
1.00	1.30	1.14	0.26	3.3%	8.503%	0.022309	0.000695	0.000738		
1.30	1.60	1.44	0.21	5.4%	7.618%	0.015817	0.000856	0.000855		
1.60	2.20	1.88	0.32	7.0%	8.022%	0.025546	0.001797	0.001787		
2.20	3.00	2.57	0.31	12.1%	9.984%	0.030966	0.003672	0.003747		
Sums:					0.302366	0.012114	0.011451			
ePM <sub>10</sub> Calculations										
d <sub>i</sub>	d <sub>i+1</sub>	d <sub>m</sub>	Δln d <sub>i</sub>	E <sub>A,i</sub>	q <sub>3σ</sub>	q <sub>3σ</sub> *Δln d <sub>i</sub>	E <sub>D,i</sub> *q <sub>3σ</sub> *Δln d <sub>i</sub>	E <sub>A,i</sub> *q <sub>3σ</sub> *Δln d <sub>i</sub>	E <sub>min</sub> (PM <sub>10</sub> )	E(PM <sub>10</sub> )
0.30	0.40	0.35	0.29	1.7%	9.412%	0.027077	0.000565	0.000448	29%	30%
0.40	0.55	0.47	0.32	2.0%	8.395%	0.026733	0.000647	0.000526		
0.55	0.70	0.62	0.24	2.4%	7.432%	0.017924	0.000526	0.000437		
0.70	1.00	0.84	0.36	2.6%	7.014%	0.025016	0.000658	0.000651		
1.00	1.30	1.14	0.26	3.3%	7.628%	0.020013	0.000623	0.000662		
1.30	1.60	1.44	0.21	5.4%	8.833%	0.018340	0.000992	0.000991		
1.60	2.20	1.88	0.32	7.0%	10.804%	0.034406	0.002421	0.002407		
2.20	3.00	2.57	0.31	12.1%	13.726%	0.042573	0.005048	0.005151		
3.00	4.00	3.46	0.29	22.2%	16.708%	0.048067	0.010339	0.010657		
4.00	5.50	4.69	0.32	40.5%	19.542%	0.062233	0.024619	0.025208		
5.50	7.00	6.20	0.24	60.0%	21.671%	0.052261	0.030598	0.031337		
7.00	10.00	8.37	0.36	71.2%	23.143%	0.082545	0.056795	0.058759		
Sums:					0.457189	0.133833	0.137235			



### The interpretation of test reports

This brief review of the test procedures, including those for addressing the testing of electrostatic charged filters, is provided for those unfamiliar with the procedures of this series of ISO standards. It is intended to assist in understanding and interpreting the results in the test report/summary. (For further details of procedures the full ISO 16890 document series shall be consulted). Air filters may rely on the effects of passive static electric charges on the fibres to achieve high efficiencies, particularly in the initial stages of their working life. Environmental factors encountered in service may affect the action of these electric charges so that the initial efficiency may drop substantially after an initial period of service. This could be offset or countered by an increase in efficiency (“mechanical efficiency”) as dust deposits build up. The reported, untreated and conditioned (discharged) efficiency shows the extent of the electrical charge effect on initial performance and indicates the potential loss of particle removal efficiency when the charge effect is completely removed and when at the same time there is no compensating increase of the mechanical efficiency. These test results should not be assumed to represent the filter performance in all possible environmental conditions or to represent all possible “real life” behaviour. This brief review of the test procedures, including those for addressing the testing of electrostatic charged filters, is provided for those unfamiliar with the procedures of this series of ISO standards. It is intended to assist in understanding and interpreting the results in the test report/summary. (For further details of procedures the full ISO 16890 document series shall be consulted). Air filters may rely on the effects of passive static electric charges on the fibres to achieve high efficiencies, particularly in the initial stages of their working life. Environmental factors encountered in service may affect the action of these electric charges so that the initial efficiency may drop substantially after an initial period of service. This could be offset or countered by an increase in efficiency (“mechanical efficiency”) as dust deposits build up. The reported, untreated and conditioned (discharged) efficiency shows the extent of the electrical charge effect on initial performance and indicates the potential loss of particle removal efficiency when the charge effect is completely removed and when at the same time there is no compensating increase of the mechanical efficiency. These test results should not be assumed to represent the filter performance in all possible environmental conditions or to represent all possible “real life” behaviour.