

2820 S. English Station Road - Louisville, KY 40299
 Tel: (502) 357-0132 Fax (502) 267-8379

TEST NO. 21-433-1

ISO 16890:2016 Air Filter Test Result Summary


Sections 2, and 4


page 1 of 3

Counter Information	Manufacturer: <u>TSI, Inc.</u>	Test Conditions	Test Flow Rate (FPM): <u>14.3 FPM / 7.25 cm/s</u>
	Model No.: <u>3330</u>		Test Aerosol: <u>Aerosolized KCl & DEHS</u>
	Serial Number: <u>3330115003</u>		Temperature (Deg F): <u>76.0</u>
	IPA Discharge Method: <input checked="" type="checkbox"/> Vapor Treated <input type="checkbox"/> IPA Dip Method		Relative Humidity (%): <u>48.2</u>
			Barometer (in Hg): <u>29.45</u>


Device Tested

Manufacturer	<u>Good Air Teams LLC</u>
Model	<u>Flat Sheet Media</u>
Part Number	<u>K9-Mask Extreme Breathe</u>
Dimensions	<u>12.5" X 5.5"</u>
Type of Media	<u>PP Lattice/PP Spunbond/N95 Blowmelt/Carbon</u>
Media Area	<u>Tested : 0.145 ft²</u>
Construction	<u>Flat Sheet Media</u>
Filter/Media Electrostatic Charge	<u>Yes</u>
Media Color	<u>Grey / Black</u>
Media Adhesive	<u>NA</u>
Sample Procurement	<u>Good Air Teams LLC</u>
Initial Filter Weight (g)	<u>NA</u>
Final Device Weight (g)	<u>NA</u>
Initial Pressure Drop ("w.c.)	<u>0.26</u>






DEHS Size .03 - 1.0 and KCL Size 1.0 - 10.0					
Range (um)	Geo. Mean	Initial Efficiency (%)	Discharged Efficiency (%)	Upstream Number of Particles per Test	
				Pre	Post
0.3-0.4	0.35	99	42	405604	761325
0.4-0.55	0.47	99	53	209473	427003
0.55-0.7	0.62	99	63	87954	192148
0.7-1.0	0.84	99	73	135251	312726
1.0-1.3	1.14	99	84	39880	96492
1.3-1.6	1.44	100	90	32293	77687
1.6-2.0	1.88	100	95	68453	165507
2.0-3.0	2.57	100	99	52429	123299
3.0-4.0	3.46	100	100	31238	68839
4.0-5.5	4.69	100	100	15948	32660
5.5-7.0	6.20	100	100	2932	5777
7.0-10.0	8.37	100	100	2320	4441



Reporting Data			
	ePM ₁	ePM _{2,5}	ePM ₁₀
Minimum	55%	67%	--
Average	77%	83%	95%
Reported	75%	80%	95%

%	Airflow	Delta p Initial	Delta p Post IPA
	(CFM)	(in WG)	(in WG)
25	3.6	0.08	0.09
50	7.2	0.14	0.16
75	10.7	0.20	0.22
100	14.3	0.26	0.28
125	17.9	0.32	0.34

ISO 16890-1										
Data Entry Table							Reporting Data			
DEHS								ePM ₁	ePM _{2,5}	ePM ₁₀
d _i	d _{i+1}	d _m	Δln d _i	E _i	E _{D,i}	E _{A,i}	Minimum	55%	67%	--
0.30	0.40	0.35	0.29	98.7%	42.1%	70.4%	Average	77%	83%	95%
0.40	0.55	0.47	0.32	99.0%	53.1%	76.1%	Reported	75%	80%	95%
0.55	0.70	0.62	0.24	99.3%	62.8%	81.0%				
0.70	1.00	0.84	0.36	99.4%	73.3%	86.4%				
KCL										
1.00	1.30	1.14	0.26	99.4%	84.3%	91.9%				
1.30	1.60	1.44	0.21	99.6%	89.6%	94.6%				
1.60	2.20	1.88	0.32	99.7%	95.1%	97.4%				
2.20	3.00	2.57	0.31	99.8%	99.2%	99.5%				
3.00	4.00	3.46	0.29	99.9%	99.9%	99.9%				
4.00	5.50	4.69	0.32	99.9%	100.0%	100.0%				
5.50	7.00	6.20	0.24	99.9%	100.0%	99.9%				
7.00	10.00	8.37	0.36	100.0%	100.0%	100.0%				
ePM ₁ Calculations										
d _i	d _{i+1}	d _m	Δln d _i	E _{A,i}	q _{3σ}	q _{3σ} *Δln d _i	E _{D,i} *q _{3σ} *Δln d _i	E _{A,i} *q _{3σ} *Δln d _i	E _{min} (PM ₁)	E(PM ₁)
0.30	0.40	0.35	0.29	70.4%	22.627%	0.065095	0.027411	0.045845	55%	77%
0.40	0.55	0.47	0.32	76.1%	19.891%	0.063343	0.033617	0.048178		
0.55	0.70	0.62	0.24	81.0%	15.837%	0.038193	0.023982	0.030949		
0.70	1.00	0.84	0.36	86.4%	11.522%	0.041097	0.030120	0.035488		
Sums:					0.207728	0.115130	0.160459			
ePM _{2,5} Calculations										
d _i	d _{i+1}	d _m	Δln d _i	E _{A,i}	q _{3σ}	q _{3σ} *Δln d _i	E _{D,i} *q _{3σ} *Δln d _i	E _{A,i} *q _{3σ} *Δln d _i	E _{min} (PM _{2,5})	E(PM _{2,5})
0.30	0.40	0.35	0.29	70.4%	22.627%	0.065095	0.027411	0.045845	67%	83%
0.40	0.55	0.47	0.32	76.1%	19.891%	0.063343	0.033617	0.048178		
0.55	0.70	0.62	0.24	81.0%	15.837%	0.038193	0.023982	0.030949		
0.70	1.00	0.84	0.36	86.4%	11.522%	0.041097	0.030120	0.035488		
1.00	1.30	1.14	0.26	91.9%	8.503%	0.022309	0.018810	0.020494		
1.30	1.60	1.44	0.21	94.6%	7.618%	0.015817	0.014174	0.014960		
1.60	2.20	1.88	0.32	97.4%	8.022%	0.025546	0.024306	0.024881		
2.20	3.00	2.57	0.31	99.5%	9.984%	0.030966	0.030713	0.030802		
Sums:					0.302366	0.203132	0.251597			
ePM ₁₀ Calculations										
d _i	d _{i+1}	d _m	Δln d _i	E _{A,i}	q _{3σ}	q _{3σ} *Δln d _i	E _{D,i} *q _{3σ} *Δln d _i	E _{A,i} *q _{3σ} *Δln d _i	E _{min} (PM ₁₀)	E(PM ₁₀)
0.30	0.40	0.35	0.29	70.4%	9.412%	0.027077	0.011402	0.019069	89%	95%
0.40	0.55	0.47	0.32	76.1%	8.395%	0.026733	0.014188	0.020333		
0.55	0.70	0.62	0.24	81.0%	7.432%	0.017924	0.011255	0.014524		
0.70	1.00	0.84	0.36	86.4%	7.014%	0.025016	0.018334	0.021602		
1.00	1.30	1.14	0.26	91.9%	7.628%	0.020013	0.016874	0.018385		
1.30	1.60	1.44	0.21	94.6%	8.833%	0.018340	0.016434	0.017346		
1.60	2.20	1.88	0.32	97.4%	10.804%	0.034406	0.032736	0.033511		
2.20	3.00	2.57	0.31	99.5%	13.726%	0.042573	0.042225	0.042348		
3.00	4.00	3.46	0.29	99.9%	16.708%	0.048067	0.048038	0.048017		
4.00	5.50	4.69	0.32	100.0%	19.542%	0.062233	0.062227	0.062207		
5.50	7.00	6.20	0.24	99.9%	21.671%	0.052261	0.052261	0.052233		
7.00	10.00	8.37	0.36	100.0%	23.143%	0.082545	0.082545	0.082526		
Sums:					0.457189	0.408520	0.432101			



The interpretation of test reports

This brief review of the test procedures, including those for addressing the testing of electrostatic charged filters, is provided for those unfamiliar with the procedures of this series of ISO standards. It is intended to assist in understanding and interpreting the results in the test report/summary. (For further details of procedures the full ISO 16890 document series shall be consulted). Air filters may rely on the effects of passive static electric charges on the fibres to achieve high efficiencies, particularly in the initial stages of their working life. Environmental factors encountered in service may affect the action of these electric charges so that the initial efficiency may drop substantially after an initial period of service. This could be offset or countered by an increase in efficiency (“mechanical efficiency”) as dust deposits build up. The reported, untreated and conditioned (discharged) efficiency shows the extent of the electrical charge effect on initial performance and indicates the potential loss of particle removal efficiency when the charge effect is completely removed and when at the same time there is no compensating increase of the mechanical efficiency. These test results should not be assumed to represent the filter performance in all possible environmental conditions or to represent all possible “real life” behaviour. This brief review of the test procedures, including those for addressing the testing of electrostatic charged filters, is provided for those unfamiliar with the procedures of this series of ISO standards. It is intended to assist in understanding and interpreting the results in the test report/summary. (For further details of procedures the full ISO 16890 document series shall be consulted). Air filters may rely on the effects of passive static electric charges on the fibres to achieve high efficiencies, particularly in the initial stages of their working life. Environmental factors encountered in service may affect the action of these electric charges so that the initial efficiency may drop substantially after an initial period of service. This could be offset or countered by an increase in efficiency (“mechanical efficiency”) as dust deposits build up. The reported, untreated and conditioned (discharged) efficiency shows the extent of the electrical charge effect on initial performance and indicates the potential loss of particle removal efficiency when the charge effect is completely removed and when at the same time there is no compensating increase of the mechanical efficiency. These test results should not be assumed to represent the filter performance in all possible environmental conditions or to represent all possible “real life” behaviour.