



Sharp and Howells Pty Ltd

CHEMICAL LABORATORIES

ABN 26 004 782 996

NATA Lab. No. 61
Est. 1922

41 Greenaway St

Bulleen Vic 3105

P: (03) 9850 9722

E: lab@sharpanhowells.com.au

www.sharpanhowells.com.au

12th September 2019

Technique Tools

15 Steele Court,

TULLAMARINE, VIC 3043

STATEMENT OF FACT:

'Lime Juice' (Trade Product of Technique Tools) used as an admixture in mortar complies with Australian Standard AS 3700 Section 11.4.2.4 requirements for;

- Compressive Strength (AS 1012.9),
- Flexural Strength (AS 3700 Appendix D6),
- and Durability (M2 Mortar) (AS 3700 Appendix E).

'Lime Juice' also complies to AS 1478.1 for air entraining admixtures (Bleed Test AS 1012.6) and chemical requirements (AS 1478.1 Section 1 & 2) when used as instructed.

'Lime Juice' has been designed for longer setting time than standard mortars (AS 1012.18).

Sharp and Howells Laboratory Reference: 19-0193

Yours faithfully,

Sharp and Howells Pty. Ltd.



John Franceschini

BSc. (Hons), C.Chem. MRACI

Director