



ANA Laboratories

Lab Number: S19J002463
Customer I.D: SARBIOYPA
Sample ID: WASTEOIL
Product Type: OIL
Sample Date: 08.08.2019
Report Date: 19.09.2019

SARVA BIO REMED, LLC
ATTENTION: SATY GANTI
25 MARIANNE DRIVE - STE. B
YORK, PA 17406

LABORATORY ANALYSIS REPORT

ANALYTICAL PARAMETER	ASTM	TYPICAL LIMITS	RESULT	UNIT
Standard Specifications for Fuel Oils (No. 4)	D396			
Total Sulfur by Ultraviolet Fluorescence	D5453	Report	1806	Parts per million
Flash Point by Pensky Martin Closed Cup	D93	55 minimum	74	Degrees Celsius
Water and Sediment	D2709	0.5 maximum	0.3	Volume %
Kinematic Viscosity @ 40 Degrees Celsius	D445	5.5 to 24.0	23.12	cSt
Ash Content	D482	0.1 maximum	0.021	Mass %
Pour Point	D97	-6 maximum	-14	Degrees Celsius

Comment: Test results are within specifications for a #4 Fuel Oil.

Signature: _____

Title: Manager, Special Testing _____