



Certificate of Compliance

Certificate: 2396134

Master Contract: 226615

Project: 2763664

Date Issued: March 24, 2015

Issued to: Societe Francaise d'Assainissement

8 rue d'Aboukir
Paris, Paris 75002
France
Attention: Florent Nguyen

The products listed below are eligible to bear the CSA Mark shown with adjacent indicators 'C' and 'US' for Canada and US or with adjacent indicator 'US' for US only or without either indicator for Canada only.



Muhunthan
Vivekananthan

Issued by: Muhunthan Vivekananthan

PRODUCTS

CLASS 3851 01 - LIQUID PUMPS

CLASS 3851 81 - LIQUID PUMPS - Certified to US Standards

Condensate removal pumps, Thermally protected, cord connected, models;

-SK5, rated 115V, 1.2A, 60W, 60Hz.

- SANICONDENS BEST; rated 115V, 1.2A, 60W, 60Hz.

APPLICABLE REQUIREMENTS

CSA-C22.2 No. 108-14 - Liquid Pumps

UL 778, 5th Ed. 2010 - Motor Operated Water Pumps