

Installation Instructions for Auxiliary Switch for DK, KDB, KD, HKD, KDC, KW, HKW, KWC, Circuit Breakers, Molded Case Switches, and K-Frame Motor Circuit Protector



Contents

Description	Page
Introduction	2
Installation	2



WARNING

DO NOT ATTEMPT TO INSTALL OR PERFORM MAINTENANCE ON EQUIPMENT WHILE IT IS ENERGIZED. DEATH, SEVERE PERSONAL INJURY, OR SUBSTANTIAL PROPERTY DAMAGE CAN RESULT FROM CONTACT WITH ENERGIZED EQUIPMENT. ALWAYS VERIFY THAT NO VOLTAGE IS PRESENT BEFORE PROCEEDING WITH THE TASK, AND ALWAYS FOLLOW GENERALLY ACCEPTED SAFETY PROCEDURES.

EATON IS NOT LIABLE FOR THE MISAPPLICATION OR MISINSTALLATION OF ITS PRODUCTS.

The user is cautioned to observe all recommendations, warnings, and cautions relating to the safety of personnel and equipment as well as all general and local health and safety laws, codes, and procedures.

The recommendations and information contained herein are based on Eaton experience and judgment, but should not be considered to be all-inclusive or covering every application or circumstance which may arise. If any questions arise, contact Eaton for further information or instructions.

1. INTRODUCTION

General Information

The auxiliary switch (Fig. 1-1) indicates circuit breaker contacts status, and is used for remote signaling and system interlocking purposes. The switch consists of one or two single-pole double-throw (SPDT) switches assembled to a plug-in module. The plug-in module is mounted in slots in the top of the trip unit; it occupies the accessory cavity in the circuit breaker frame, and is positioned so that the switch actuator arm rests against the molded crossbar. Each SPDT switch has one "a" and one "b" contact. When the molded crossbar is in the contacts-closed position, the "a" contact of each SPDT switch is closed and the "b" contact is open. When the molded crossbar is in the tripped or contacts-open position, the "a" contact is open and the "b" contact is closed.




Fig. 1-1 Auxiliary Switch Installed in K-Frame Circuit Breaker

Table 1-1 lists electrical rating data for the auxiliary switch.

Table 1-1. Auxiliary Switch Electrical Rating Data ① ② ③

Maximum Voltage (V)	Freq.	Maximum Current (A)	Dielectric Withstand Voltage (V)
600	50/60 Hz	6	2500
125	DC	0.5 ④	
250	DC	0.25 ④	

Notes:

- ① Endurance - 6000 electrical operations plus 4000 mechanical operations
- ② Pigtail wire size - No. 18 AWG (0.82 mm²)
- ③ Terminal block is listed for use with one or two No. 18 to No. 14 AWG solid or stranded copper wire. Torque is 7 lb-in (0.8 N.m).
- ④ Non-inductive load

Depending on the model ordered, connections for the auxiliary switch are in one of four forms. The standard wiring configuration is pigtail leads exiting the rear of the base directly behind the accessory. Optional configurations include a terminal block mounted on the same side of the base as the accessory, leads exiting the side of the base where the accessory is mounted, and leads exiting the rear of the base on the side opposite the accessory. The 18-inch long pigtail leads are color coded for identification; identification labels are provided for pigtail leads and terminal block points. For allowable locations of all accessories, refer to Frame Book 29-103.

Note: No more than three pigtail leads can be routed through the rear trough in the circuit breaker base. When the walking beam interlock is used with the circuit breaker, the rear trough cannot be used for accessory pigtail leads.

This instruction leaflet (I.L.) gives detailed procedures to install the auxiliary switch.

2. INSTALLATION

Note: The auxiliary switch can be field-installed in KD, HKD, and KDC circuit breakers under UL File E64983.

For sealed circuit breakers, Underwriters Laboratories, Inc. UL489 requires that internal accessories be installed at the factory. The auxiliary switch is listed for factory installation under UL File E7819.

Where local codes and standards permit and UL listing is not required, internal accessories can be field-installed in DK and KDB sealed circuit breakers. In this case, UL listing becomes invalid and the label should be removed.

Before attempting to install the accessory, check that the catalog number is correct and that the rating of the accessory satisfies job requirements.

The auxiliary switch, shown in kit form in Fig. 2-1, can be installed in the right or left accessory mounting cavity of a 2-, 3-, or 4-pole circuit breaker. An auxiliary switch must be installed in the circuit breaker before the circuit breaker is mounted in an electrical system. To install the auxiliary switch, perform the following procedures:

Note: A circuit breaker that is mounted in an electrical system must be removed to install the accessory. To ensure correct accessory installation, the circuit breaker must be placed on a horizontal surface.




Fig. 2-1. Auxiliary Switch Kit



WARNING

BEFORE REMOVING A CIRCUIT BREAKER INSTALLED IN AN ELECTRICAL SYSTEM, MAKE SURE THE CIRCUIT BREAKER IS SWITCHED TO THE OFF POSITION AND THERE IS NO VOLTAGE PRESENT WHERE WORK IS TO BE PERFORMED. SPECIAL ATTENTION SHOULD BE PAID TO REVERSE FEED APPLICATIONS TO ENSURE NO VOLTAGE IS PRESENT. THE VOLTAGES IN ENERGIZED EQUIPMENT CAN CAUSE DEATH OR SEVERE PERSONAL INJURY.

- 2-1. Switch circuit breaker to OFF position.
- 2-2. Disconnect and remove circuit breaker from installation and terminal connections.

Note: For new circuit breaker installation, trip unit must be installed in circuit breaker before attempting to install auxiliary switch. Refer to I.L. 29C603, I.L. 29C604, or I.L. 29C605 for instructions on how to install the trip unit.

- 2-3. Remove cover screws and cover.

Note: For an auxiliary switch having rear or oppositeside exiting pigtail leads, thread leads through center trough in

side of case before attempting to insert mounting bracket. Pigtail leads exiting in this manner should be eased through trough as mounting bracket is inserted into trip unit retaining slots. Use center slot for leads exiting side of the circuit breaker.

- 2-4. Route wiring to meet installation requirements. (Fig. 2-2)




Fig. 2-2. Accessory Wiring Options



CAUTION

PIGTAIL WIRES SHOULD BE FORMED AND ROUTED TO CLEAR ALL MOVING PARTS WHEN ACCESSORY IS PROPERLY INSTALLED. PIGTAIL LEADS COULD BE DAMAGED IF IN CONTACT WITH MOVING PARTS.

- 2-5. Insert the auxiliary switch as described in the following steps (Fig. 2-3):




Fig. 2-3. Auxiliary Switch Installation Positions

- a. Slide auxiliary switch plug-in module into slots until retaining clip snaps into trip unit. Auxiliary switch operating arm(s) must be between accessory operating projection on molded crossbar and arc extinguisher. For terminal block assemblies, slide terminal block into mounting slot on side of base as plug-in module is being positioned.
- b. If required, complete routing of leads to opposite-side through rear wiring trough.
- c. For double auxiliary switch pigtail leads, attach wire marking labels to bundle of three leads for each switch. (Markers designated 1 and 2 are provided.)



CAUTION

WHEN INSTALLING CIRCUIT BREAKER COVER, MAKE SURE THAT ALL INTERNAL PARTS ARE IN PLACE:

- **SLIDING HANDLE BARRIERS ARE POSITIONED SO THAT THE HANDLE OPENING IS ALIGNED WITH THE HANDLE.**
- **PIGTAIL LEADS ARE CLEAR OF COVER.**

WHEN REMOVED AND REINSTALLED, THREAD-FORMING SCREWS TRY TO REFORM THE THREADS IN THE CIRCUIT BREAKER BASE. CARE SHOULD BE TAKEN EVERY TIME A THREAD-FORMING SCREW IS USED TO ENSURE THAT THE SCREW STARTS IN THE ORIGINAL THREADS. DAMAGED THREADS CAN RESULT IN IMPROPER CIRCUIT BREAKER COVER RETENTION.




Fig. 2-4. Cover Screw Installation Positions

- 2-6. With circuit breaker handle in OFF position and accessory pigtail leads (if used) routed as required, install circuit breaker cover. Secure with pan-head screws followed by thread-forming screws, as shown in Fig. 2-4.




Fig. 2-5. Preferred Mounting Location for Accessory Nameplate Labels

- 2-7. Remove and discard UL listing label on DK and KDB circuit breakers only.
- 2-8. Place accessory labels (supplied with kit) on circuit breaker. (See Fig. 2-5.)

Note: Accessory labels show connection diagram for auxiliary switch. Pigtail leads are color coded red, black, and blue.

- 2-9. est auxiliary switch(es). Connect continuity tester or ohmmeter across pigtail leads or terminal block connections. Check continuity as follows:
 - a. Circuit breaker handle OFF — "a" contact(s) — open. "b" contact(s) — closed.
 - b. Circuit breaker handle ON — "a" contact(s) — closed. "b" contact(s) — open.
 - c. Press PUSH-TO-TRIP button — "a" contact(s) — open "b" contact(s) — closed.
 - d. If auxiliary switch(es) fails test, make sure that auxiliary switch(es) module is properly seated in trip unit slots. If auxiliary switch(es) appears to be correctly installed and the problem persists, contact CutlerHammer.

- 2-10. Install circuit breaker.

- 2-11. Connect auxiliary switch as required (see Fig. 2-6).




Fig. 2-6. Auxiliary Switch Connection Diagram

Eaton assumes no responsibility for malfunctioning accessories installed by the customer.

NOTES:

NOTES:

NOTES:

The instructions for installation, testing, maintenance, or repair herein are provided for the use of the product in general commercial applications and may not be appropriate for use in nuclear applications. Additional instructions may be available upon specific request to replace, amend, or supplement these instructions to qualify them for use with the product in safety-related applications in a nuclear facility.

The information, recommendations, descriptions, and safety notations in this document are based on Eaton's experience and judgment with respect to Retrofitting of Power Breakers. This instructional literature is published solely for information purposes and should not be considered all-inclusive. If further information is required, you should consult an authorized Eaton sales representative.

The sale of the product shown in this literature is subject to the terms and conditions outlined in appropriate Eaton selling policies or other contractual agreement between the parties. This literature is not intended to and does not enlarge or add to any such contract. The sole source governing the rights and remedies of any purchaser of this equipment is the contract between the purchaser and Eaton.

NO WARRANTIES, EXPRESSED OR IMPLIED, INCLUDING WARRANTIES OF FITNESS FOR A PARTICULAR PURPOSE OR MERCHANTABILITY, OR WARRANTIES ARISING FROM COURSE OF DEALING OR USAGE OF TRADE, ARE MADE REGARDING THE INFORMATION, RECOMMENDATIONS, AND DESCRIPTIONS CONTAINED HEREIN.

In no event will Eaton be responsible to the purchaser or user in contract, in tort (including negligence), strict liability or otherwise for any special, indirect, incidental or consequential damage or loss whatsoever, including but not limited to damage or loss of use of equipment, plant or power system, cost of capital, loss of power, additional expenses in the use of existing power facilities, or claims against the purchaser or user by its customers resulting from the use of the information, recommendations and description contained herein.

Eaton Corporation
Electrical Group
1000 Cherrington Parkway
Moon Township, PA 15108
United States
877-ETN-CARE (877-386-2273)
Eaton.com

© 2014 Eaton Corporation
All Rights Reserved
Printed in Dominican Republic
Publication No. IL 29C122C
Part No. 6632C64H04
April 2015