



## Catalog No. TJ400S

Description: ENCLOSURE NEMA 1 SURFACE 400A

UPC No 783164013429

## Home > Circuit Breakers > Circuit Breaker Enclosures

GE's circuit breaker enclosures are UL Listed, CSA Certified and are suitable for use as service equipment (except as noted). The short circuit rating of the enclosure/circuit breaker combination is equal to the short circuit rating of the installed circuit breaker. ACCESSORIES Neutral Kit (non-GF applications) TNIA600 400S Amps 400 A

Descriptors	
Category GO Schedule	Circuit Breaker Enclosures
GO Schedule	B3
Specifications	
Enclosure Type	NEMA Type 1

•	
Enclosure Type	NEMA Type 1
Mounting	Surface
Frame Type	J600
Amperage	400 A
UL/CUL Listing	CSA, UL
Material	Steel
Drawings-Outline and Dimensional	139C5497SH3
GSA Compliance	No

Dimensions	
Height	27.4 in
Height Depth	6.4 in
Width	15.4 in
Weight	34.7 lb

geindustrial.com Created on: 12/04/2018

Publications		
Title	<b>Publication No.</b>	<b>Publication Type</b>
NEMA Type 1 enclosure, 400 amp max. Product Numbers TJ400F and TJ400S.		Drawings-Outline and
1 page outline drawing in .pdf format.	139C5497-SH3	Dimensional

**Additional Documentation:** Visit our Publication Library to find technical documentation, time current curves, CSI Specifications and promotional literature.

geindustrial.com Created on: 12/04/2018