

# AWTA PRODUCT TESTING

Australian Wool Testing Authority Ltd - trading as AWTA Product Testing  
A.B.N 43 006 014 106

1st Floor, 191 Racecourse Road, Flemington, Victoria 3031  
P.O Box 240, North Melbourne, Victoria 3051  
Phone (03) 9371 2400

## TEST REPORT

**Client :** National Flooring Distributors  
58 Blanck Street  
Ormeau QLD 4208

**Test Number :** 21-003649  
**Issue Date :** 29/07/2021  
**Print Date :** 29/07/2021

**Sample Description** Clients Ref : "Kalara"  
Laminate Flooring  
Colour : Coastal Blackbutt

EN 13329-2000  
Annex E

### Laminate Floor Coverings - Specifications, Requirements and Test Methods Determination of Abrasion Resistance and Abrasion Classification

Date of Testing	28/07/2021		
Load	500 g		
Wheel Type	S-42		
Specimen	1	2	3
Initial Wear Point	>4000	>4000	>4000
Abrasion Class	AC4 (≥4000)		

Cycles

Abrasive paper changed every 200 cycles

244048

53013

Page 1 of 1

© Australian Wool testing Authority Ltd  
Copyright - All Rights Reserved

Samples, and their identifying descriptions have been provided by the client unless otherwise stated.  
AWTA Ltd makes no warranty, implied or otherwise, as to the source of the tested samples. The above test results relate only to the sample or samples tested. The above test results are designed to provide THE CLIENT WITH GUIDANCE INFORMATION ONLY.

This document shall not be reproduced except in full and shall be rendered void if amended or altered.

This document, the names AWTA Product Testing and AWTA Ltd may be used in advertising providing the content and format of the advertisement have been approved in advance by the Managing Director of AWTA Ltd.



Fiona McDonald

APPROVED SIGNATORY

MICHAEL A. JACKSON B.Sc.(Hons)  
MANAGING DIRECTOR