## **AWTA PRODUCT TESTING**

Australian Wool Testing Authority Ltd - trading as AWTA Product Testing A.B.N 43 006 014 106

1st Floor, 191 Racecourse Road, Flemington, Victoria 3031 P.O Box 240, North Melbourne, Victoria 3051 Phone (03) 9371 2400

## **TEST REPORT**

Client: National Flooring Distributors

> 58 Blanck Street Ormeau QLD 4208

Test Number :

21-002667

**Issue Date Print Date** 

30/07/2021 4/08/2021

**Sample Description** 

Clients Ref: "Mirage"

Laminate Flooring End Use: Flooring

Nominal Composition: **HDF** 

Nominal Mass per Unit Area/Density:

850kg/m3

Nominal Thickness: 8mm

AS ISO 9239.1-2003

Reaction to Fire Tests for Floorings. Determination of the Burning Behaviour using a

**Radiant Heat Source** 

Date of Sample Arrival

28-05-2021

**Date Tested** 

CHF Value

29-07-2021

Lengin	
Width	
HF-30 Value	
TII -50 Value	
Length	
Width	

8.8 1 6.2

1

29

4

1

5.7

2 6.2

2

13

2

6.2

3 6.8

3

5.5

Mean

Mean

5.8

6.4 kW/m<sup>2</sup>

kW/m<sup>2</sup>

3 4

Mean

15 %.min %.min

kW/m²

kW/m<sup>2</sup>

Blistering

Length

Width

Smoke Value

Yes

Page 1 of 2

244677

Australian Wool Testing Authority Ltd Copyright - All Rights Reserved

51943

Accredited for compliance with ISO/IEC 17025 - Testing

Samples and their identifying descriptions have been provided by the client unless otherwise stated. AWTA Ltd makes no warranty, implied or otherwise, as to the source of the tested samples. The above test results relate only to the sample or samples tested. This document shall not be reproduced except in full and shall be rendered void if amended or altered. This document, the names AWTA Product Testing and AWTA Ltd may be used in advertising providing the content and format of the advertisement have been approved by the Managing Director of AWTA Ltd.

> Chris Campbell APPROVED SIGNATORY

MICHAEL A. JACKSON B.Sc.(Hons)

0204/11/06

## **AWTA PRODUCT TESTING**

Australian Wool Testing Authority Ltd - trading as AWTA Product Testing
A.B.N 43 006 014 106

1st Floor, 191 Racecourse Road, Flemington, Victoria 3031 P.O Box 240, North Melbourne, Victoria 3051 Phone (03) 9371 2400

## **TEST REPORT**

Client: National Flooring Distributors

58 Blanck Street Ormeau QLD 4208 **Test Number** : 21-002667 **Issue Date** : 30/07/2021

Print Date : 4/08/2021

The test results relate to the behaviour of the test specimens of a product under the particular conditions of the test, they are not intended to be sole criterion for assessing the potential fire hazard of the product in use.

Sample was conditioned in accordance with BSEN 13238:2010 at a temperature of 23±2°C and relative humidity of 50±5% for a minimum of 48 hours prior to testing.

Each specimen was clamped to a substrate of 6mm thick fibre reinforced cement board prior to testing.

Results in accordance with section 8.4 have not been included in the report. They are available upon request.

HF30 not reported as flame out time occurred before 30 minutes.

244677 51943 Page 2 of 2

 Australian Wool Testing Authority Ltd Copyright - All Rights Reserved



Accredited for compliance with ISO/IEC 17025 - Testing

Samples and their identifying descriptions have been provided by the client unless otherwise stated. AWTA Ltd makes no warranty, implied or otherwise, as to the source of the tested samples. The above test results relate only to the sample or samples tested. This document shall not be reproduced except in full and shall be rendered void if amended or altered. This document, the names AWTA Product Testing and AWTA Ltd may be used in advertising providing the content and format of the advertisement have been approved by the Managing Director of AWTA Ltd.

Chris Campbell

MICHAEL A. JACKSON B.Sc.(Hons)

APPROVED SIGNATORY