


Australian Wool Testing Authority Ltd - trading as AWTA Product Testing A.B.N 43 006 014 106

1st Floor, 191 Racecourse Road, Flemington, Victoria 3031 P.O Box 240, North Melbourne, Victoria 3051 Phone (03) 9371 2400

TEST REPORT

ł	National Flo 58 Blanck S Ormeau QL			Test Number Issue Date Print Date	· : :	21-00267 2/08/202 ⁻ 2/08/2021	1	
Sample Des	scription	Clients Ref : "Terrace" Vinyl flooring planks End Use : Flooring Nominal Composition : PVC Nominal Mass per Unit Area/Density : Nominal Thickness : 4.5mm	7.6kg/m2					
AS ISO 9239.1-2003		Reaction to Fire Tests for Floorings. Determination of the Burning Behaviour using a Radiant Heat Source						
		Date of Sample Arrival		28-05-2021				
		Date Tested	02-08-2021					
		CHF Value	1	2	3	Mean		
		Length	8.0	7.8 7.	8	7.9	kW/m²	
		Width	8.8	-	-	-	kW/m²	
		Smoke Value	1	2	3	Mean		
		Length	206	240 21	3	220	%.min	
		Width	189	-	-	-	%.min	
		Blistering				Yes		



APPROVED SIGNATORY

Page 1 of 2



MICHAEL A. JACKSON B.Sc.(Hons)

C

244411

Australian Wool Testing Authority Ltd Copyright - All Rights Reserved



Australian Wool Testing Authority Ltd - trading as AWTA Product Testing A.B.N 43 006 014 106

1st Floor, 191 Racecourse Road, Flemington, Victoria 3031 P.O Box 240, North Melbourne, Victoria 3051 Phone (03) 9371 2400

TEST REPORT

Client : National Flooring Distributors 58 Blanck Street Ormeau QLD 4208

Test Number	:	21-002676
Issue Date	:	2/08/2021
Print Date	:	2/08/2021

The test results relate to the behaviour of the test specimens of a product under the particular conditions of the test, they are not intended to be sole criterion for assessing the potential fire hazard of the product in use.

Sample was conditioned in accordance with BSEN 13238:2010 at a temperature of 23±2°C and relative humidity of 50±5% for a minimum of 48 hours prior to testing.

Results in accordance with section 8.4 have not been included in the report. They are available upon request.

HF30 not reported as flame out time occurred before 30 minutes.

Each specimen was adhered to a substrate of 6mm thick fibre reinforced cement board using Roberts 656 adhesive and clamped prior to testing.

244411

51952

C Australian Wool Testing Authority Ltd Copyright - All Rights Reserved



Accredited for compliance with ISO/IEC 17025 - Testing

Samples and their identifying descriptions have been provided by the client unless otherwise stated. AWTA Ltd makes no warranty, implied or otherwise, as to the source of the tested samples. The above test results relate only to the sample or samples tested. This document shall not be reproduced except in full and shall be rendered void if amended or altered. This document, the names AWTA Product Testing and AWTA Ltd may be used in advertising providing the content and format of the advertisement have been approved by the Managing Director of AWTA Ltd.

Chris Campbell

APPROVED SIGNATORY





