


## CLEARANCE FROM COMBUSTIBLES



| MODEL  | "A" DIM. | WATTS | VOLTS | AMPS | BTU's |
|--------|----------|-------|-------|------|-------|
| W512   | 19"      | 500   | 120   | 4.2  | 1706  |
| W7512  | 19"      | 750   | 120   | 6.3  | 2559  |
| W1012  | 33"      | 1000  | 120   | 8.3  | 3412  |
| W1512  | 33"      | 1500  | 120   | 12.5 | 5118  |
| W2024  | 39"      | 2000  | 240   | 8.3  | 6824  |
| W2524  | 39"      | 2500  | 240   | 10.4 | 8530  |
| W3024  | 61 1/4"  | 3000  | 240   | 12.5 | 10236 |
| WD3024 | 33"      | 3000  | 240   | 12.5 | 10236 |
| W4024  | 61 1/4"  | 4000  | 240   | 16.7 | 13648 |
| WD4024 | 39"      | 4000  | 240   | 16.7 | 13648 |
| WD5024 | 39"      | 5000  | 240   | 20.8 | 17060 |
| WD6024 | 61 1/4"  | 6000  | 240   | 25   | 20472 |

OTHER VOLTAGES ALSO AVAILABLE: 208, 277, 480





INFRATECH.

www.infratech-usa.com

344 W 157th Street Gardena, California 90248 Phone: (310) 354-1250 Fax: (310) 523-3674

DESCRIPTION


W-SERIES HEATER CAD DRAWING


Apr. 12, 2019


DRAWN BY: MD


NA


## **INSTALLATION TYPES**














## WARNINGS:

Do not use Surface Mount Brackets.
This Frame is ONLY to be used on a flat non-sloped ceiling.
Heater Body must face straight down and be flush with the finished ceiling.
Frame and Heater cannot be installed on a pitched angle.
Accessible Junction Box must be installed

outside of sealed drywall pocket.

Use Licensed Electrician ONLY.

Must use  $\frac{5}{8}$ " type "X" drywall.

Must use supplied 4 foot Hi-Temp Fixture
Whip and Hi-Temp Ceramic Wire Nuts.

Please contact factory for longer length
Hi-Temp Fixture Whips available for purchase.

Discard Surface Mounting Brackets provided
with Heater and use "L" Brackets.

## NOTES:

Heater suspends (Gravity) by resting on adjustable "L" Brackets in flush mount fixture. Mounting holes on Surface Flange to be determined and drilled by Contractor/Installer. Coil excess flex into heater cavity.

After 4 hours of continuous use, a 15 minute cool down period is recommended for maximum heater longevity. See controls brochure for timer options.

| INFRAT<br>www.infratech-  | usa.com            | 344 W 157th Street<br>ardena, California 90248<br>Phone: (310) 354-1250<br>Fax: (310) 523-3674 |  |  |  |
|---|--------------------|--|--|--|--|
| ITEM #:<br>18-2300  | MATERIAL: 304      | MATERIAL:<br>304 S.S. #4 FINISH  |  |  |  |
| DESCRIPTION: W-39 FLUSH MOUNT FRAME<br>(FOR USE WITH 39" HEATERS) |                    |  |  |  |  |
| NOTES:<br>SUPPLIE   | ED w/ HI-TEMP FIXT | URE WHIP   |  |  |  |
| DATE:   | SCALE:             | DRAWN BY:  |  |  |  |
| Dec. 16, 2019   | N/A                | CL   |  |  |  |