

# LOCATIONS TO AVOID - 2-in-1 P4010ACLEDSCA & 3-in-1 P4010ACLEDSCOCA INCORRECT INSTALLATIONS

**DO NOT INSTALL WITHIN 0.9 M (3')  
OF COLD AIR RETURNS OR OTHER  
HIGH AIR-FLOW AREAS**



**DO NOT INSTALL WITHIN 0.9 M (3')  
OF COLD AIR RETURNS OR OTHER  
HIGH AIR-FLOW AREAS**



**DO NOT INSTALL WITHIN  
0.9 M (3') OF CEILING OR WHOLE  
HOUSE VENTILATING FANS**



**DO NOT INSTALL WITHIN 0.9 M (3')  
OF A BATHROOM THAT CONTAINS  
A TUB OR SHOWER**



**INSTALL ALARMS AT LEAST 30.5 CM (12")  
AWAY FROM FLUORESCENT LIGHTS**



**AVOID EXCESSIVELY DUSTY, DIRTY  
OR GREASY AREAS. DUST PARTICLES  
MAY CAUSE NUISANCE ALARMS OR  
FAILURE TO ALARM.**

