



Air Vent System

The following are recommendations. Please check with your city for requirements

- Mechanical ventilation system exhausts fumes to the exterior (0.6 CFM/FT²)
- Mechanical ventilation system brings air into the salon (0.12 CFM/FT² + 20 CFM/occupant)
- Makeup air and exhaust air ducts are separate; there is no mixing recirculating, or partial makeup air
- Source capture at manicure tables and foot baths (capable of exhausting a minimum of 50 CFM per station)

TAURUS

Example Wall Hook-Up
Whale Spa does NOT provide hook-up parts. Always check municipal specific ordinances and local codes.

4" outlet from Wall

2" TEE

Recommended height from floor 10 1/2 "

FLOOR

