

Confirmation

LEED

On 14/12/2015, Eurofins Product Testing A/S received a sample of paint with the product name:

ECOS APP

supplied by

Imperial Paints LLC

The sample was supplied as being representative of the manufactured product, and it has been tested as paint in accordance with the relevant CDPH 01350, ISO 11890-2 and ASTM D6886 testing standards (See test report no. 392-2015-00421705_H_EN and 392-2016-00086005).

The test results of the tested coating indicate that the product qualifies for LEED v4 and LEED 2009 specifications on VOC emissions and/or VOC content by complying with:


VOC emissions specifications in LEED EQ credit "Low-emitting products":

- the requirements of CDPH-IAQ (California Department of Public Health); and a TVOC below 0.5 mg/m³ in both office and class room.

VOC content specifications in LEED EQ credit "Low-emitting products":

- the requirements of SCAQMD rule 1113 (2011)
- the requirements of the EU Decopaint Directive 2004/42/CE

18 March 2016



Thomas Bjerring
Analytical Service Manager