



Intertek Testing Services
ETL SEMKO

EC TYPE EXAMINATION CERTIFICATE

Certificate Number EC 304. Rev. 1.

This is to certify that samples representative of production of the appliances listed below have been examined and found to comply with the essential requirements listed in Annex I of Council Directive of 29 June 1990 on the approximation of the laws of the Member States relating to appliances burning gaseous fuels (90/396/EEC).

Certificate type: Supplementary
Original or Supplementary

Report Numbers: 02007501/A and 03011375

Appliance type: Ball valves


Appliance names: Art 100 "Elite" Type (1/4" to 2" sizes in range)

Product Identification No. 359BN304

Manufactured by: IVR Valvole A Sfera S.P.A
Via Risorgimento, 9 – Fraz. Ara
28075 Grignasco (NO)
Italy

Scope: At temperatures between -20°C and 60°C on all 2nd and 3rd family gas categories at inlet pressures up to and not exceeding 20 bar

ITS Testing & Certification Ltd
Notified Body 0359


C. Davey
Certifying Officer
6 August 2003

Issue date:

Note: The certificate revision has been raised to add the 1/4" version of the valve to the existing range.