



Ingress Protection (IP) Rating Certificate

iButtonLink, LLC, confirms that the T-Probe Pipe, excluding the connector, from the end of the wire sheath to the end of the sensor, has been tested and rates

IPx6/IPx7

in which the device is protected against water projected in powerful jets by a 12.5 mm nozzle against the enclosure from any direction and is protected against the effect of “temporary” immersion in liquid between 15 cm and 1 m. Protection against solid particles has not been tested.

Please note that this confirmation is given to the best of our present knowledge and belief. Nothing herein represents and/or may be interpreted as warranty within the meaning of the applicable warranty law.

Sarah Isberner, Engineering Team Lead

October 11, 2017