



Power Certification Form - 16.50 / 16.87 / 15.50 / VZ14.00

The intimus® models 16.50/16.87/15.50/VZ14.00 shredder/baler combinations all require a 220Volt, 3-phase, 60 cycle power source fused at 50 AMPS per phase. These shredders are equipped with 3-pole, 4-wire, grounded plugs, Leviton #7765-C or equivalent. This plug requires usage of matching locking connector, Leviton #7764-C or equivalent. Only one line is required to run the shredder/baler combination. The voltage should not vary more than plus or minus 5 volts under full load.

Power Certification

Date: _____

Telephone: _____

Customer: _____

Please provide us with a measured voltage supply and return to us within one (1) week.

Voltage: _____ Phase: _____ Cycle: _____

Information above furnished by: _____

Name / Title

Company

Phone

Please note: Any charges incurred as a result of incorrect voltage information is not the responsibility of Martin Yale Industries, Inc. whether corrections are made either in house or in the field. Powering this unit on a voltage or cycle different than that is listed above may result in a lower machine speed and/or reduced capacity.

We require this information as soon as possible in order to get your equipment installed on schedule. Your installation will not be scheduled until this form is completed and returned.

Martin Yale Industries, Inc.
251 Wedcor Avenue
Wabash, IN 46992
Phone: (800) 225-5644 • Fax: (260) 563-4575
www.martinyale.com • www.intimus.com • sales@intimus.com