

Gas Boiler Diesel Boiler Air to water HP

if an AW HP installation was a buffer tank used

Appliance make

Appliance model

Serial No,

The appliance has been installed in accordance with the manual.

The appliance & system has been flushed before commissioning.

Installed in a
New or existing system

Underfloor system

Flow Return to Radiators

Manifold to radiators

Mixed system

DHW format if applicable

pre heated by buffer

Indirect coiled cylinder

On demand from boiler

Installation address

city

Date completed

System inhibitor dosage - Magnetic filtration - System calibration

Inhibitor is critical to ensure the system remains clear of lime scale and to ensure potential corrosion is prevented.

We recommend **Kamco System-safe DM** at a dose of 500ml per 100L of water content

for your guidance 1m of single panel radiator @ 600h holds approx. 2.7L.

1m of 10mm pipe = 0.08L - 15mm pipe = 0.18L - 20mm pipe 0.33L

Dose

Has a Magnetic Filter been installed (required under warranty for Gas boilers and AW HPs)

Was a flue gas analyser used to set this appliance If yes please enter the appropriate achieved readings below

Component failure due to incorrect combustion settings is not covered under warranty we recommend the use of a calibrated analyser

CO

CO2

Contractors Declaration (in all cases appliance or system)

This installation has been carried out to comply with relevant building / plumbing and electrical code . where required Gas and electrical certification is provided by the contractor . All aspects of commissioning have been carried out as prescribed in the appliance manual .

The Customer/user. has been given guidance in regard to correct and efficient use the appliance and system controls, advice for topping up the system and how to use the system controls. manuals for this system have been left with the user.

Fitters name (print)

Signature

Company name (print)

Customer, End user - installation Sign Off

The system installation is complete, I am happy with the products supplied and the standard of workmanship. I have been shown how to use my system and I understand that under the terms of warranty annual service is required

Please include your

e mail address - This will only be used to send you a service reminder it will not be shared

Customers name (print)

Signature

E mail

This document must be lodged with Heat IQ in order to activate your appliance warranty

Please scan and send a signed copy to, sales@heatiq.co.nz - or post a signed copy of this document to PO BOX 530 Wanganui. We will acknowledge receipt of this completed commissioning notice and advise the activated warranty within 14 days of receipt.

An automated annual service reminder will be sent to the Installer and to the end user for the period of warranty.

Failure to lodge this commissioning certificate will limit warranty to 1 year only from date of purchase

If you do not receive warranty confirmation by e-mail within 14 working days please contact us 06 3447392

Terms and conditions and detail of warranty cover are available on our website, www.heatiq.co.nz

