



APPLICATION NOTE AN2012

SEQUENCE HEATERS

P.O. Box 2956 · Syracuse · New York · 13220
Phone: (315) 433-1150 Fax: (315) 433-1521
Toll Free US & Canada (800) 334-0837
Email: sales@infitec.com

email: sales@infitec.com
engineering@infitec.com

SEQUENCE HEATERS

Input voltage is applied at all times. When the thermostat closes, Heat Relay 1 turns on and Timer 1 Delay On begins. Upon completion of Timer 1 Delay On, Heat Relay 2 turns on and Timer 2 Delay On begins. Upon completion of Timer 2 Delay On, Heat Relay 3 turns on. When the thermostat opens, Heat Relay 1 turns off and Heat Relays 2 & 3 sequence off according to Timer 1 & Timer 2 Delay Off period.

