FFP CANTERBURY LTD
FIRE PROTECTION SYSTEMS
BUILDING WARRANT OF FITNESS
WORKPLACE SAFETY SOLUTIONS



**SS 6** 

## Riser Mains Monthly by Owner

## **BUILDING MAINTENANCE RECORD**

**SPECIFIED SYSTEM 6: Riser Mains** 

1. INSPECTION FREQUENCY:

MONTHLY BY OWNER OR BUILDING MANAGER

Note: Annual IQP inspection is completed on WHITE Forms at back of register.

- 2. MONTHLY CHECK MUST ENSURE THAT:-
  - All outlets are clear from obstruction
  - All caps in place where fitted
  - Signage is clean and legible
  - Valve closed and no tampering is evident
  - No leaks visible
  - All faults and repairs noted below

## THIS PAGE TO BE COMPLETED BY OWNER/MANAGER

MONTH	DATE	SIGNATURE	COMMENTS