



广微测
Gmicro Testing

GUANGDONG DETECTION CENTER OF MICROBIOLOGY

REPORT FOR ANALYSIS

Report №.

2020FM17773R01Ea

Name of Sample

Air purifier

Applicant

MARTIN INDUSTRIES LTD

Test Type

Entrustment Test



Address: Building 66, No.100 Central Xian Lie Road, Guangzhou, China

Postcode: 510070

Tel: +86 20 87137666

Fax: +86 20 87137668

Website: www.gddcm.com



广微测
Gmicro Testing

GUANGDONG DETECTION CENTER OF MICROBIOLOGY

REPORT FOR ANALYSIS

Report No.: 2020FM17773R01Ea Verification Code: 08427513



Name of Sample	Air purifier	Test Type	Entrustment Test
Applicant	MARTIN INDUSTRIES LTD	Address	UNIT 8 MILTON BUSINESS CENTRE WICK DRIVE NEW MILTON HAMPSHIRE BH25 6RH
Sample Source	Submitted for Testing by the Applicant	Sample Quantity	One Sample Submitted
Spec and Lot No of Sample	AXP800 200V 75W	State and Characteristic	Silver gray; Machine
Sample Received Date	2020-06-16	Test Completion Date	2020-07-17
Test Standard and Method	Refer to GB 21551.3-2010 Appendix A		
Item Tested	Air virus elimination effect		
Test Conclusion	<p>The test data of the sample(s) is attached to the page(s) of this report.</p> <p>Issue Date: DISTRIBUTEDATE# (Official Seal)</p> <p style="text-align: right;">(provided by the)</p>		
Remarks	Manufacturer/Supplier: applicant)		

Editor:

Chen Yingting

Verifier:

Li Suqian

Approver:

Xie Xiaobao



GUANGDONG DETECTION CENTER OF MICROBIOLOGY

ANALYSIS AND TEST RESULT

Report No.: 2020FM17773R01Ea

Virus and host cell	Action Time	Serial Number	Air virus content (TCID ₅₀ /m ³)	Removal rate (%)
H1N1 <i>Influenza A virus</i> (A/PR/8/34) Host cell: MDCK	0 (CK)	1	1.94×10^6	
		2	2.44×10^6	
		3	1.73×10^6	
	2h	1	<97.3	99.98
		2	<97.3	99.97
		3	<97.3	99.97

Note: The natural decay of the microorganisms in the air has been eliminated.

Photo of the sample:



(Blank Below)

Remarks	The machine was tested in a 30m ³ test chamber.
---------	------------------------------------------------------------



Report №.: 2020FM17773R01Ea

Notice Items

1. The Test report is invalid if not affixed with Authorized Stamp of Test and Paging Seal.
2. The Test report is invalid without signature of verifier and approver.
3. The Test report is invalid if being supplemented, deleted or altered.
4. Without prior written permission, the report cannot be reproduced, except in full.
5. Unless otherwise stated, the results shown in this test report refer only to the sample(s) submitted.
6. Any dispute of the report must be raised to the testing body within 15 days after the report is received, exceeding which the dispute will not be accepted.
7. For the tested sample(s) submitted by the applicant, the sample information in the test report is provided by the applicant and the laboratory is not responsible for its authenticity.
8. This test report is for reference only to the applicant and does not have a proof of effect for others.

