HEADQUARTERS: 914 WEST PATAPSCO AVENUE • BALTIMORE, MARYLAND 21230 • PHONE (410) 354-3300 • FAX (410) 354-3313

July 28, 2021

National Building Supply, Inc. 2000 East Broadway Suite 225 Columbia, Mo 65201

Dear Michael Thrift,

Enclosed is the EMC test report for compliance testing of the National Building Supply, Inc., ULTRA NT SCIF Barrier – Perforated to be evaluated under the requirements of IEEE-299: 2006 – IEEE Standard Method for Measuring the Effectiveness of Electromagnetic Shielding Enclosures.

Thank you for using the services of Eurofins Electrical and Electronic Testing NA, Inc. If you have any questions regarding these results or if Eurofins Electrical and Electronic Testing NA, Inc. can be of further service to you, please feel free to contact me.

Sincerely yours,

Eurofins Electrical and Electronic Testing NA, Inc.

Michelle Tawmging

Documentation Department

Michelle Tawnging

Reference: (\National Building Supply, Inc.\EMC113344-IEEE)



Certificates and reports shall not be reproduced except in full, without the written permission of Eurofins Electrical and Electronic Testing NA, Inc. While use of the A2LA logo in this report reflects Eurofins Electrical and Electronic Testing NA, Inc. accreditation under these programs, the report must not be used by the client to claim product certification, approval, or endorsement by A2LA or any agency of the Federal Government. This letter of transmittal is not a part of the attached report.

Eurofins Electrical and Electronic Testing NA, Inc. (Eurofins E&E North America) is part of the Eurofins Electrical & Electronics (E&E) global compliance network.



Electromagnetic Compatibility Criteria Test Report

for the

National Building Supply, Inc. ULTRA NT SCIF Barrier – Perforated

To be evaluated under the Requirements of **IEEE-299**

Report: EMC113344-IEEE

July 28, 2021

Prepared For:

National Building Supply, Inc. 2000 East Broadway Suite 225 Columbia, Mo 65201

> Prepared By: Eurofins Electrical and Electronic Testing NA, Inc. 914 West Patapsco Ave., Baltimore MD 21230

Electromagnetic Compatibility Criteria Test Report

for the

National Building Supply, Inc. **ULTRA NT SCIF Barrier – Perforated**

To be evaluated under the Requirements of **IEEE-299**

Testing Performed By:

Brandon Tracy Electromagnetic Compatibility Lab Prepared By:

Michelle Tawmging **Documentation Department**

Steve Pitta

Director, Operations Strategy

Test Report Status Sheet

Revision	Test Report Date	Reason for Revision	
Ø	July 28, 2021	Initial Issue.	

Table of Contents

I.	Ove	rview	1
	A.	Overview	
	В.	References	
II.	Equ	ipment Configuration	3
	Α.	Overview	4
	В.	Test Site	4
	C.	Description of Test Sample	
	D.	Modifications	
		a) Modifications to EUT	4
		b) Modifications to Test Standard	4
	E.	Disposition of EUT	
III.	IEE	E-299.	
	A.	Shielding Effectiveness Measurement Data	
	B	Test Fauinment	30



National Building Supply, Inc. ULTRA NT SCIF Barrier – Perforated

List of Figures

Figure 1. 100MHz to 18GHz Shielding Effectiveness Result Vertical Polarity	
Figure 2. 100MHz to 18GHz Shielding Effectiveness Result Horizontal Polarity	8
Figure 3. 100MHz to 18GHz Shielding Effectiveness Minimum Result	9
List of Tables	
Table 1. Noise Floor Measurement, Direct Measurement, Dynamic Range Measurement	6
Table 2. Foil Sheet Wallpaper	7
Table 3 Test Equipment	30

Overview

National Building Supply, Inc. ULTRA NT SCIF Barrier – Perforated

A. Overview

Model(s) Tested:	ULTRA NT SCIF Barrier – Perforated		
Model(s) Covered:	ULTRA NT SCIF Barrier – Perforated		
Size: (HxWxD)	22 x 22 inches		
Analysis:	The results obtained relate only to the item(s) tested.		
Prepared by:	Michelle Tawmging		

B. References

IEEE-299: 2006	Measuring the Effectiveness of Electromagnetic Shielded Enclosures		
ISO/IEC 17025: 2017	General Requirements for the Competence of Testing and Calibration Laboratories		

Equipment Configuration

A. Overview

Eurofins Electrical and Electronic Testing NA, Inc. was contracted by National Building Supply, Inc. to perform testing on the ULTRA NT SCIF Barrier – Perforated.

This document describes the test setups, test methods, required test equipment, and the test limit criteria used to perform compliance testing of the National Building Supply, Inc., ULTRA NT SCIF Barrier – Perforated.

In accordance with §2.955(a) (3), the following data is presented in support of the verification of the National Building Supply, Inc., ULTRA NT SCIF Barrier – Perforated. National Building Supply, Inc. should retain a copy of this document which should be kept on file for at least two years after the manufacturing of the ULTRA NT SCIF Barrier – Perforated has been **permanently** discontinued, as per §2.955(b).

The results obtained relate only to the item(s) tested.

B. Test Site

All testing was performed at Eurofins Electrical and Electronic Testing NA, Inc., 914 West Patapsco Ave., Baltimore MD 21230. All equipment used in making physical determinations is accurate and bears recent traceability to the National Institute of Standards and Technology.

Radiated Emissions measurements were performed in a semi anechoic chamber. In accordance with §2.948(a)(3), a complete site description is contained at Eurofins Electrical and Electronic Testing NA, Inc. In accordance with §2.948(d), Eurofins Electrical and Electronic Testing NA, Inc. has been accredited by the National Voluntary Laboratory Accreditation Program (Lab Code: 100273-0).

C. Description of Test Sample

The ULTRA NT SCIF Barrier – Perforated is the Equipment Under Test (EUT) which is a foil sheet for shielding.

D. Modifications

i. Modifications to the EUT

No modifications were made to the EUT.

ii. Modifications to the Test Standard

No modifications were made to the test standard.

E. Disposition of EUT

The test sample including all support equipment (if any), submitted to the Electro-Magnetic Compatibility Lab for testing was returned to National Building Supply, Inc. upon completion of testing.

IEEE-299



A. Shielding Effectiveness Measurement Data

Test Results: Testing was completed by Brandon Tracy on July 27, 2021.

Environmental Conditions:

Test date: 7/27/2021		Customer:	National Building Supply, Inc (NAT46)	Temperature:
Engineer:	Brandon Tracy	METrak #: 113344		25.5 C
Specification/Yr: IEEE 299-2006		EUT Name:	Perforated Foil Sheet	Rel. Humidity:
		Mode/Config:	n/a	40%
		Pass Date:	n/a	Setup Photo File Name:
Calibration/Detection System/EUT Setup verified by/Date:	BT 7/27/2021			n/a

Test Data:

Frequency (MHz)	Noise Floor Measurement (dBm)		Direct Measurement (dBm)		Dynamic Range (dB)		RBW	Sig Gen Drive Level (dBm)	
	Co-Axial	Co-Planar	Co-Axial	Co-Planar	Co-Axial	Co-Planar			
0.01	-112.38	-111.37	-59.9	-62.92	52.48	48.45	20 Hz	22	
0.15	-115.41	-112.95	-42.95	-45.07	72.46	67.88	20 Hz	22	
15.00	-128.79	-127.58	-53.72	-56.09	75.07	71.49	20 Hz	22	
Frequency (MHz)	Noise Measurem		Dir Measur (dB	rement	Dynamic Range (dB)		RBW	Sig Gen Drive Level	
	Horizontal	Vertical	Horizontal	Vertical	Horizontal	Vertical		(dBm)	
30.00	-73.72	-81.67	-17.25	0.61	56.47	82.28	1 kHz	22	
31.30	-108.46	-102.55	-15.26	-3.03	93.2	99.52	1 kHz	22	
34.80	-113.97	-115.68	-7.8	-4.47	106.17	111.21	1 kHz	22	
38.30	-114.18	-111.89	0.21	-8.42	114.39	103.47	1 kHz	22	
100.00	-105.25	-109.3	3.32	6.51	108.57	115.81	1 kHz	22	
400.00	-115.05	-116.37	-1.92	1.72	113.13	118.09	1 kHz	22	
800.00	-114.44	-115.51	-3.13	-2.46	111.31	113.05	1 kHz	22	
1000.00	-114.25	-115.46	-24.43	-22.46	89.82	93	1 kHz	15	
2000.00	-112.55	-112.25	-24.53	-28.26	88.02	83.99	1 kHz	15	
4000.00	-114.1	-113.62	-26.8	-26.38	87.3	87.24	1 kHz	15	
5000.00	-114.69	-113.66	-26.23	-25.96	88.46	87.7	1 kHz	15	
10000.00	-110.83	-111.25	-27.9	-28.22	82.93	83.03	1 kHz	15	
18000.00	-109.89	-108.24	-34.74	-34.41	75.15	73.83	1 kHz	15	

Table 1. Noise Floor Measurement, Direct Measurement, Dynamic Range Measurement

National Building Supply, Inc. ULTRA NT SCIF Barrier – Perforated

Frequency (MHz)	Foil Sheet Wallpaper Measurement (dBm)		Foil Sheet Wall Effective	Minimum SE (dB)		
(MIIIZ)	Co-Axial	Co-Planar	Co-Axial	Co-Planar	(ub)	
0.01	-86.73	-81.29	26.83	18.37	18.37	
0.15	-85.07	-80.33	42.12	35.26	35.26	
15.00	-124.17	-123.03	70.45	66.94	66.94	
Frequency	Foil Sheet Wallpaper Measurement (dBm)			Foil Sheet Wallpaper Shielding Effectiveness (dB)		
(MHz)	Horizontal	Vertical	Horizontal	Vertical	(dB)	
30.00	-84.15	-79.82	66.9	80.43	66.9	
31.30	-102.25	-99.82	86.99	96.79	86.99	
34.80	-104.23	-103.35	96.43	98.88	96.43	
38.30	-99.64	-103	99.85	94.58	94.58	
100.00	-81.62	-91.23	84.94	97.74	84.94	
400.00	-95.32	-97.08	93.4	98.8	93.4	
800.00	-92.19	-97.73	89.06	95.27	89.06	
1000.00	-101.82	-103.83	77.39	81.37	77.39	
2000.00	-99.37	-102.33	74.84	74.07	74.07	
4000.00	-97.56	-100.11	70.76	73.73	70.76	
5000.00	-99.46	-103.65	73.23	77.69	73.23	
10000.00	-93.45	-98.61	65.55	70.39	65.55	
18000.00	-93.43	-97.1	58.69	62.69	58.69	
Frequency (GHz)	Horizontal (dB)	Vertical (dB)	Min (dB)			
0.10	84.94	97.74	84.94			
0.40	93.4	98.8	93.4			
0.80	89.06	95.27	89.06			
1.00	77.39	81.37	77.39			
2.00	74.84	74.07	74.07			
4.00	70.76	73.73	70.76			
5.00	73.23	77.69	73.23			
10.00	65.55	70.39	65.55			
18.00	58.69	62.69	58.69			

Table 2. Foil Sheet Wallpaper




Figure 1. 100MHz to 18GHz Shielding Effectiveness Result Vertical Polarity




Figure 2. 100MHz to 18GHz Shielding Effectiveness Result Horizontal Polarity






Figure 3. 100MHz to 18GHz Shielding Effectiveness Minimum Result




Figure 4. 100MHz to 10GHz Shielding Effectiveness Summary (Both Polarities)

National Building Supply, Inc. ULTRA NT SCIF Barrier – Perforated

Test Photographs:



Figure 5: Dynamic Range (Biconical Horizontal)




Figure 6: Dynamic Range (Biconical Vertical)



Figure 7: Dynamic Range (Horn Antenna Horizontal)




Figure 8: Dynamic Range (Horn Antenna Vertical)






Figure 9: Dynamic Range (Loop Coaxial)




Figure 10: Dynamic Range (Loop Coplanar)



Figure 11: Dynamic Range (LPA Horizontal)



Figure 12: Dynamic Range (LPA Vertical)





Figure 13: Test Sample (Biconical Horizontal Rx)




Figure 14: Test Sample (Biconical Horizontal Tx)





Figure 15: Test Sample (Biconical Vertical Rx)





Figure 16: Test Sample (Biconical Vertical Tx)






Figure 17: Test Sample (Horn Antenna Horizontal Rx)





Figure 18: Test Sample (Horn Antenna Horizontal Tx)





Figure 19: Test Sample (Horn Antenna Vertical Rx)





Figure 20: Test Sample (Horn Antenna Vertical Tx)






Figure 21: Test Sample (Loop Coaxial Rx)





Figure 22: Test Sample (Loop Coaxial Tx)






Figure 23: Test Sample (Loop Coplanar Rx)





Figure 24: Test Sample (Loop Coplanar Tx)

a eurofins





Figure 25: Test Sample (LPA Horizontal Rx)



Figure 26: Test Sample (LPA Horizontal Tx)






Figure 27: Test Sample (LPA Vertical Rx)





Figure 28: Test Sample (LPA Vertical Tx)





Figure 29: Test Sample Mounted (Rx Side)





Figure 30: Test Sample Mounted (Tx Side)

B. Test Equipment

Calibrated test equipment utilized during testing was maintained in a current state of calibration per the requirements of ISO/IEC 17025:2017.

MET #	EQUIPMENT	MANUFACTURER	MODEL#	CAL DATE	CAL DUE
1T8836	ANTENNA (ACTIVE 12" LOOP)	A.H. SYSTEMS	SAS-563P	FUNCTIONALLY VERIFIED	
1T8837	ANTENNA (ACTIVE 12" LOOP)	A.H. SYSTEMS	SAS-563B	FUNCTIONAL	LY VERIFIED
1T4701	ANTENNA, BICONICAL	ETS-LINDGREN	3109	FUNCTIONAL	LY VERIFIED
1T2658	ANTENNA; BICON	EMCO	3109	03/04/2020	09/04/2021
1T4483	ANTENNA; HORN	ETS-LINDGREN	3117	FUNCTIONAL	LY VERIFIED
1T4757	ANTENNA; HORN	ETS-LINDGREN	3117	06/29/2020	12/29/2021
1T8372	LOG PERIODIC ANTENNA	A.H.SYSTEMS, INC.	SAS-517	FUNCTIONALLY VERIFIED	
1T8373	LOG PERIODIC ANTENNA	A.H. SYSTEMS, INC.	SAS-517	FUNCTIONALLY VERIFIED	
1T4710	SIGNAL GENERATOR	НР	8648D	07/01/2020 01/01/2022	
1T4739	SIGNAL GENERATOR	AGILENT TECHNOLOGIES	N5183A	09/16/2019 09/16/2021	
1T4681	SPECTRUM ANALYZER (PSA)	AGILENT TECHNOLOGIES	E4448A	04/07/2020	10/07/2021
1T8854C	RF CABLE	MEGAPHASE	CAGE1GVT4	FUNCTIONALLY VERIFIED	
1T8854D	RF CABLE	MEGAPHASE	CAGE1GVT4	FUNCTIONALLY VERIFIED	

Table 3. Test Equipment

Note: Functionally verified test equipment is verified using calibrated instrumentation at the time of testing.

End of Test Report