

CLASSIFICATION OF REACTION TO FIRE BASED ON DIN EN 13501-1:2010-01

- Translation -

No. of Classification Report:

K-2300/949/16-MPA BS

Client:

YSHIELD GmbH & Co. KG
Am Schulplatz 2
94099 Ruhstorf

Issued by:

Materialprüfanstalt für das Bauwesen
Beethovenstraße 52
38106 Braunschweig

Notified body No.:

0761-CPD

Product:

Shielding paint
Product designation: „YSHIELD sheilding paint HSF54“

Issue No.:

1st issue

Date of issue:

20/02/2017

Validity:

not restricted

This Classification Report consists of 6 pages



This document may only be circulated as a complete text without alterations. Excerpts or abridged versions of this document are subject to approval in writing of MPA Braunschweig. Translations of this document that are made without the approval of MPA Braunschweig must bear the note "translation of the German original not examined by MPA Braunschweig". The first sheet of this document and the page carrying the signatures bear the official stamp of MPA Braunschweig. Documents without signature and the official stamp are invalid. The test material has been fully used.

1 Introduction

This Classification Report describes the classification that is assigned to the construction product "YSHIELD sheilding paint HSF54"* on the basis of the method specified in DIN EN 13501-1:2010-01.

2 Details of the classified product

2.1 Type and application

The construction product "YSHIELD sheilding paint HSF54"* is an acrylic coating which is used as primer which is coated with a standard dispersion paint.

2.2 Description

The construction product "YSHIELD sheilding paint HSF54"* is described in detail in the Test Reports that are listed in section 3.1 below and on which this classification is based.

3 Test report and results as the basis for the classification

3.1 Reports

Name of testing laboratory	Client	Report No.	Test method and date
MPA Braunschweig	YSHIELD GmbH & Co. KG Am Schulplatz 2 94099 Ruhstorf	2300/949/16-a - Sta of 20/02/2017	DIN EN ISO 11925-2:2011-02
		2300/949/16-b - Sta of 20/02/2017	DIN EN 13823: 2015-02

* Specifications provided by the manufacturer

3.2 Results for the product „YSHIELD sheilding paint HSF54“*

Test method	Parameter	No. Of tests	Ergebnisse	
			Continuous Parameters Mean values (m)	Compliance Parameters
DIN EN 13823	<i>FIGRA_{0,2 MJ}</i>	3	30,3 ¹⁾	--
	<i>FIGRA_{0,4 MJ}</i>		0,0 ¹⁾	--
	<i>THR_{600s} [MJ]</i>		0,57 ¹⁾	--
	<i>LFS < Edge</i>		no ¹⁾	compliance
	<i>SMOGRA [m²/s²]</i>		0,0 ¹⁾	--
	<i>TSP_{600s} [m²]</i>		9,9 ¹⁾	--
	Burning debris / droplets		no ¹⁾	compliance
DIN EN ISO 11925-2				
Surface flame attack 30 s	Fs ≤ 150 mm	6	--	compliance
	Burning debris / droplets		Ignition of filter paper	--
Edge flame attack 30 s	Fs ≤ 150 mm	6	--	compliance
	Burning debris / droplets		Ignition of filter paper	--

* Specifications provided by the manufacturer

4 Classification and field of direct application

4.1 Reference of classification

This classification has been carried out in accordance with DIN EN 13501-1:2010-01.

4.2 Classification

The construction product "YSHIELD sheilding paint HSF54" in relation to its fire behaviour is classified:*

B

The additional classification in relation to smoke production is:

s1

The additional classification in relation to burning debris / droplets is:

d0

The classification format for the reaction to fire for construction products except for floorings, pipe insulation is:

Fire behaviour		Smoke production			burning debris / droplets	
B	--	s	1	--	d	0

Classification of reaction to fire: B-s1, d0

* Classification of reaction to fire

4.3 Field of application

This classification covers the following product parameter

<i>Product</i>	<i>Parameter</i>	<i>Validity range of the classification</i>
YSHIELD sheilding paint HSF54*	<i>Application rate (wet)</i>	165 g/m ² mm ± 15,0 g/m ²
	<i>Density</i>	1440 kg/m ³ ± 140 kg/m ³
	<i>Colour</i>	black
Top layer	<i>Type</i>	Dispersion paint
	<i>Application rate</i>	200 g/m ² ± 20,0 g/m ²
	<i>Density</i>	1270 kg/m ³ ± 120 kg/m ³
	<i>Colour</i>	white
Substrate	<i>Type</i>	Gypsum boards as well as substrate with reaction to fire class A1 and A2-s1,d0 with a density ≥ 450 kg/m ³ and thickness ≥ 12,0 mm in accordance to the regulate referred to DIN 13238:2010, section 5.3.2.1 and 5.3.2.2, 5.3.2.4
	<i>Distance to other flat construction products</i>	Direct application (≤ 0 mm), use only in conjunction with top layer

End-use application:

-Paint to shield electromagnetic fields.*


*Specifications provided by the manufacturer

5 Notes

- 5.1 The classification in section 4 only applies to the construction material described in section 2 above. When combined with other construction materials (e.g. other components, other weight per unit areas or other thicknesses), its reaction to a fire may be adversely influenced so that the above classification no longer applies. The reaction to fire of the construction material when combined with other materials or made from other components or with other thicknesses etc. has to be separately.
- 5.2 This Classification Report is not a type approval or product certification document, and it does not replace the approval that may be required under the German building law (State Government Building Regulations).

This document is the translated version of Test Report 2300/949/16 dated 20/02/2017 translated on 20/02/2017. The legally binding text is the aforementioned German Test Report.

Signature


N. Stachowski B.Sc.
Official in charge



Confirmed


ORR Dr.-Ing. G. Blume
Head of Testing Laboratory