



DEPARTMENT OF REGULATORY AND ECONOMIC RESOURCES (RER)
BOARD AND CODE ADMINISTRATION DIVISION

NOTICE OF ACCEPTANCE (NOA)

MIAMI-DADE COUNTY
PRODUCT CONTROL SECTION

11805 SW 26 Street, Room 208
Miami, Florida 33175-2474
T (786) 315-2590 F (786) 315-2599

www.miamidade.gov/economy

GAF
1 Campus Drive
Parsippany, NJ 07054

SCOPE:

This NOA is being issued under the applicable rules and regulations governing the use of construction materials. The documentation submitted has been reviewed and accepted by Miami-Dade County RER - Product Control Section to be used in Miami-Dade County and other areas where allowed by the Authority Having Jurisdiction (AHJ).

This NOA shall not be valid after the expiration date stated below. The Miami-Dade County Product Control Section (in Miami-Dade County) and/or the AHJ (in areas other than Miami-Dade County) reserve the right to have this product or material tested for quality assurance purposes. If this product or material fails to perform in the accepted manner, the manufacturer will incur the expense of such testing and the AHJ may immediately revoke, modify, or suspend the use of such product or material within their jurisdiction. RER reserves the right to revoke this acceptance if it is determined by Miami-Dade County Product Control Section that this product or material fails to meet the requirements of the applicable building code.

This product is approved as described herein and has been designed to comply with the Florida Building Code including the High Velocity Hurricane Zone of the Florida Building Code.

DESCRIPTION: GAF Premium Acrylic HydroStop® System over Lightweight Concrete Decks.

LABELING: Each unit shall bear a permanent label with the manufacturer's name or logo, city, state and following statement: "Miami-Dade County Product Control Approved", unless otherwise noted herein.

RENEWAL of this NOA shall be considered after a renewal application has been filed and there has been no change in the applicable building code negatively affecting the performance of this product.

TERMINATION of this NOA will occur after the expiration date or if there has been a revision or change in the materials, use, and/or manufacture of the product or process. Misuse of this NOA as an endorsement of any product, for sales, advertising or any other purposes shall automatically terminate this NOA. Failure to comply with any section of this NOA shall be cause for termination and removal of NOA.

ADVERTISEMENT: The NOA number preceded by the words Miami-Dade County, Florida, and followed by the expiration date may be displayed in advertising literature. If any portion of the NOA is displayed, then it shall be done in its entirety.

INSPECTION: A copy of this entire NOA shall be provided to the user by the manufacturer or its distributors and shall be available for inspection at the job site at the request of the Building Official.

This NOA renews and revises NOA No. 18-0321.08 and consists of pages 1 through 7.

The submitted documentation was reviewed by Jorge L. Acebo.



NOA No.: 23-0327.10
Expiration Date: 06/22/28
Approval Date: 07/06/23
Page 1 of 7

ROOFING SYSTEM APPROVAL

Category:	Roofing
Sub-Category:	Liquid Applied Roof System
Deck Type:	Lightweight Concrete
Material:	Elastomeric
Maximum Design Pressure:	-502.5 psf.

TRADE NAMES OF PRODUCTS MANUFACTURED OR LABELED BY APPLICANT:

TABLE 1

<u>Product</u>	<u>Container Sizes</u>	<u>Test Specification</u>	<u>Product Description</u>
GAF Cleaning Concentrate (formerly known as United Cleaning Concentrate)	1 & 5 Gallon	Proprietary	Biodegradable cleaning agent with specific functional ingredients for degreasing and removing soils and biological residues for proper cleaning of roof surfaces.
GAF Metal Roof Primer (formerly known as Acrylex 400 Primer)	2 & 5 Gallon	Proprietary	Primer used in direct to metal applications to stabilize and protect metal surfaces.
GAF BarrierGuard® Surface Coating (formerly known as HydroStop® BarrierGuard® Waterproofing)	2 & 5 Gallon	Proprietary	Priming and waterproofing compound for masonry surfaces.
GAF SureBond Primer	2 & 5 Gallon	Proprietary	Acrylic primer used for sealing masonry, metal and chalky surfaces.
GAF UniBase Primer	5 Gallon	Proprietary	Low viscosity, highly penetrating, acrylic polymer primer.
GAF Lock-Down Primer	1 & 5 Gallon	Proprietary	Moisture-Cure Urethane Primer For Corrosion Protection On Metal Surfaces
FlexSeal™ Sealant	1 & 5 Gallon or 1 qt. Tube	TAS 139	Solvent-based, elastomeric sealant.
GAF Premium Acrylic HydroStop® Base Coat	2 & 5 Gallon	Proprietary	Acrylic elastomeric waterproofing compound used as a base layer in the GAF Premium Acrylic HydroStop® System.
GAF Premium Fabric (formerly known as HydroStop® PremiumCoat® Fabric)	Rolls	Proprietary	Reinforcing fabric for the GAF Premium Acrylic HydroStop® System and/or GAF BarrierGuard® Surface Coating.
GAF Premium Brush-Grade Acrylic Flashing (formerly known as HydroStop® PremiumCoat® Butter Grade Flashing)	2 & 5 Gallon	Proprietary	Acrylic elastomeric sealant for bridging gaps, filling voids and low lying roof areas.



TRADE NAMES OF PRODUCTS MANUFACTURED OR LABELED BY APPLICANT:

TABLE 1

<u>Product</u>	<u>Container Sizes</u>	<u>Test Specification</u>	<u>Product Description</u>
GAF Spray-Grade Acrylic Flashing (formerly known as United Coatings™ Roof Mate Liquid Fabric)	5 & 55 Gallon	TAS 139	Water based, sprayable high elastic flashing compound.
GAF Premium Acrylic HydroStop® Top Coat	2 & 5 Gallon	ASTM D6083	Acrylic elastomeric waterproofing compound used as a top layer in the GAF Premium Acrylic HydroStop® System.
GAF TrafficCoat Pedestrian Surface Coating	2 & 5 Gallon	Proprietary	Acrylic elastomeric waterproofing compound used as a smooth or textured non-skid surfacing layer over the GAF Premium Acrylic HydroStop® System.

APPROVED INSULATIONS:

TABLE 2

<u>Product Name</u>	<u>Product Description</u>	<u>Manufacturer (With Current NOA)</u>
N/A	N/A	N/A

APPROVED FASTENERS:

TABLE 3

<u>Fastener Number</u>	<u>Product Name</u>	<u>Product Description</u>	<u>Dimensions</u>	<u>Manufacturer (With Current NOA)</u>
1	Drill-Tec™ Base Sheet Fastener (1.7 in.)	G-90 galvanized fastener with plate for base sheet attachment to gypsum decks and lightweight insulating concrete decks. Coated with CR-10 fluorocarbon coating.	1.125" head 1.75" length. with 2.75" Galvalume steel stress plate.	GAF
2	Drill-Tec™ Base Sheet Fastener E (1.7 in.)	Galvanized fastener with plate for base sheet attachment to gypsum decks and lightweight insulating concrete decks.	2.7" head x 1.7" long	GAF



EVIDENCE SUBMITTED:

<u>Test Agency</u>	<u>Test Identifier</u>	<u>Test Name/Report</u>	<u>Date</u>
Atlantic and Caribbean Roof Consulting, LLC	16-003	TAS 114	03/04/16
Trinity ERD	4696.04.97.1	TAS 114	07/11/97
PRI Construction Materials Technologies LLC	376T0340	Proprietary	10/28/22
	376T0341	Proprietary	10/28/22
	376T0159	ASTM D6083	08/31/21
	GAF-777-02-01	ASTM D6083	09/15/17
	GAF-659-02-01	Proprietary	06/03/16
	GAF-660-02-01	Proprietary	06/03/16
	GAF-661-02-01	Proprietary	06/03/16
	GAF-662-02-01	Proprietary	06/07/16
	GAF-664-02-01	Proprietary	06/03/16
	GAF-665-02-01	Proprietary	06/03/16
	GAF-667-02-01	TAS 139	07/01/16
	GAF-668-02-01	TAS 139	07/01/16
	GAF-671-02-01	TAS 139	07/01/16
	GAF-674-02-01	Proprietary	06/01/16
	GAF-676-02-01	Proprietary	06/01/16
	GAF-678-02-01	Proprietary	07/14/16
	GAF-679-02-01	Proprietary	06/01/16
	GAF-680-02-01	Proprietary	06/01/16
UL LLC	R6935	UL790	05/11/23

DECK STRESS ANALYSIS CALCULATIONS/REPORTS

<u>Engineer/Agency</u>	<u>Identifier</u>	<u>Assemblies</u>	<u>Date</u>
Robert Nieminen, P.E.	Signed/Sealed Calculations	F(1)	01/14/16



APPROVED ASSEMBLIES

Membrane Type: Liquid Applied Membrane

Deck Type 4: Lightweight Concrete, non-insulated

Deck Description: Minimum 300 psi Mearlcrete lightweight insulating concrete cast over steel deck.

Deck: Min. 22 ga., type B, Grade 80, vented steel decking attached to support spaced maximum 5' o.c. using Traxx/5 fasteners spaced at 6" o.c. Steel deck side laps are attached 18" o.c. with Traxx 1 fasteners.

This Tested Assembly has been analysed for allowable deck stress. See Evidence Submitted Table.

System Type F(1): GAF Premium Acrylic HydroStop® System applied directly to lightweight concrete.

GAF Premium Acrylic HydroStop® products shall be installed in accordance with the manufacturer's specifications. The following are minimum installation guidelines. Consult the manufacturer's specifications or Technical Representative for specific/complete installation instructions.

All General and System limitations apply.

Membrane: GAF BarrierGuard® Surface Coating (formerly known as HydroStop® BarrierGuard® Waterproofing) applied in two (2) coats at a rate of 0.67 gal./sq. per coat.

GAF SureBond Primer applied at rate of 0.5 gal./sq.

GAF Premium Acrylic HydroStop® Base Coat is brush applied at a minimum rate of 1.25 gal./sq.

GAF Premium Fabric (formerly known as HydroStop® PremiumCoat® Fabric) is embedded in the wet GAF Premium Acrylic HydroStop® Base Coat within 4 in. wide seams and is saturated with additional GAF Premium Acrylic HydroStop® Base Coat brush-applied at a minimum rate of 1.25 gal./sq.

Two (2) or more coats of GAF Premium Acrylic HydroStop® Top Coat are applied at a minimum rate of 0.75 gal./sq. per coat.

**Surfacing:
(Optional)** GAF TrafficCoat Pedestrian Surface Coating applied per manufacturer's installation instructions.

Maximum Design

Pressure: -52.5 psf (See General Limitation #9)



Membrane Type: Liquid Applied Membrane

Deck Type 4: Lightweight Concrete, non-insulated

Deck Description: Minimum 205 psi generic lightweight concrete cast over structural concrete.

*The generic lightweight concrete shall record a minimum characteristic resistance force (MCRF) of 77.93 lbf when tested with the Drill-Tec™ Base Sheet Fastener E (1.7 in.) or the Drill-Tec™ Base Sheet Fastener (1.7 in.) per TAS 105.

Deck: Structural Concrete

System Type F(2): GAF Premium Acrylic HydroStop® System applied directly to lightweight concrete.

GAF Premium Acrylic HydroStop® products shall be installed in accordance with the manufacturer's specifications. The following are minimum installation guidelines. Consult the manufacturer's specifications or Technical Representative for specific/complete installation instructions.

All General and System limitations apply.

Membrane: GAF BarrierGuard® Surface Coating (formerly known as HydroStop® BarrierGuard® Waterproofing) applied in two (2) coats at a rate of 0.67 gal./sq. per coat.

GAF SureBond Primer applied at rate of 0.5 gal./sq.

GAF Premium Acrylic HydroStop® Base Coat is brush applied at a minimum rate of 1.25 gal./sq.

GAF Premium Fabric (formerly known as HydroStop® PremiumCoat® Fabric) is embedded in the wet GAF Premium Acrylic HydroStop® Base Coat base coat within 4 in. wide seams and is saturated with additional GAF Premium Acrylic HydroStop® Base Coat brush-applied at a minimum rate of 1.25 gal./sq.

Two (2) or more coats of GAF Premium Acrylic HydroStop® Top Coat are applied at a minimum rate of 0.75 gal./sq. per coat.

**Surfacing:
(Optional)**

GAF TrafficCoat Pedestrian Surface Coating applied per manufacturer's installation instructions.

Maximum Design

Pressure: -502.5 psf (See General Limitation #9)

MANUFACTURER'S REQUIREMENTS:

1. Contractor must be a GAF HydroStop® "Approved Applicator", trained and familiar with the details and specifications published by the manufacturer. Proof of this qualification shall be provided in written form from the manufacturer.
2. Refer to GAF's published installation instructions for detailed installation requirements and recommendations.



LIGHTWEIGHT INSULATING CONCRETE SYSTEM LIMITATIONS:

1. If mechanical attachment to the structural deck through the lightweight insulating concrete is proposed, a field withdrawal resistance testing shall be performed to determine equivalent or enhanced fastener patterns and density. All testing and fastening design shall be in compliance with Testing Application Standard TAS 105 and Roofing Application Standard RAS 117, calculations shall be signed and sealed by a Florida registered Professional Engineer, Registered Architect, or Registered Roof Consultant.
2. For steel deck application where specific deck construction is not referenced: The deck shall be a minimum 22 gage attached with 5/8" puddle welds with weld washers at every flute with maximum deck spans of 5 ft. o.c.
3. For systems where specific lightweight insulating concrete is not referenced, the minimum design mix shall be a minimum of 300 psi.

GENERAL LIMITATIONS:

1. Fire classification is not part of this acceptance, refer to a current Approved Roofing Materials Directory for fire ratings of this product.
2. Insulation may be installed in multiple layers. The first layer shall be attached in compliance with Product Control Approval guidelines. All other layers shall be adhered in a full mopping of approved asphalt applied within the EVT range and at a rate of 20-40 lbs./sq., or mechanically attached using the fastening pattern of the top layer.
3. All standard panel sizes are acceptable for mechanical attachment. When applied in approved asphalt and/or adhesives panel size shall be 4' x 4' maximum.
4. An overlay and/or recovery board insulation panel is required on all applications over closed cell foam insulations when the base sheet is fully mopped. If no recovery board is used the base sheet shall be applied using spot mopping with approved asphalt, 12" diameter circles, 24" o.c.; or strip mopped 8" ribbons in three rows, one at each sidelap and one down the center of the sheet allowing a continuous area of ventilation. Encircling of the strips is not acceptable. A 6" break shall be placed every 12' in each ribbon to allow cross ventilation. Asphalt application of either system shall be at a minimum rate of 12 lbs./sq.

Note: Spot attached systems shall be limited to a maximum design pressure of -45 psf.

5. Fastener spacing for insulation attachment is based on a Minimum Characteristic Force (F') value of 275 lbf., as tested in compliance with Testing Application Standard TAS 105. If the fastener value, as field-tested, are below 275 lbf. insulation attachment shall not be acceptable.
6. Fastener spacing for mechanical attachment of anchor/base sheet or membrane attachment is based on a minimum fastener resistance value in conjunction with the maximum design value listed within a specific system. Should the fastener resistance be less than that required, as determined by the Building Official, a revised fastener spacing, prepared, signed and sealed by a Florida registered Professional Engineer, Registered Architect, or Registered Roof Consultant may be submitted. Said revised fastener spacing shall utilize the withdrawal resistance value taken from Testing Application Standards TAS 105 and calculations in compliance with Roofing Application Standard RAS 117.
7. Perimeter and corner areas shall comply with the enhanced uplift pressure requirements of these areas. Fastener densities shall be increased for both insulation and base sheet as calculated in compliance with Roofing Application Standard RAS 117. Calculations prepared, signed and sealed by a Florida registered Professional Engineer, Registered Architect, or Registered Roof Consultant **(When this limitation is specifically referred within this NOA, General Limitation #9 will not be applicable.)**
8. All attachment and sizing of perimeter nailers, metal profile, and/or flashing termination designs shall conform with Roofing Application Standard RAS 111 and applicable wind load requirements.
9. The maximum designed pressure limitation listed shall be applicable to all roof pressure zones (i.e. field, perimeters, and corners). Neither rational analysis, nor extrapolation shall be permitted for enhanced fastening at enhanced pressure zones (i.e. perimeters, extended corners and corners). **(When this limitation is specifically referred within this NOA, General Limitation #7 will not be applicable.)**
10. All products listed herein shall have a quality assurance audit in accordance with the Florida Building Code and Rule 61G20-3 of the Florida Administrative Code.

END OF THIS ACCEPTANCE