



**NOTE:**

1. ROOFING MEMBRANE SHALL EXTEND UNDER THE ROOF DRAIN COMPRESSION CLAMP RING.
2. ALL DRAIN COMPONENTS SHALL BE MADE OF CAST IRON UNLESS APPROVED BY THE ROOF MEMBRANE MANUFACTURER TO USE ANOTHER MATERIAL.
3. SLOPE INSULATION TOWARDS DRAIN.
4. PRIMING - REFER TO HYDROSTOP® SPECIFICATIONS FOR DECK PRIMING REQUIREMENTS.



**HYDROSTOP™**

**STANDARD ROOF DRAIN DETAIL**

SYSTEM

**HS**

DRAWING #

**504**

www.gaf.com  
1 Campus Drive  
Parsippany, NJ  
07054

ROOF PENETRATION  
SERIES

SCALE

N.T.S.

ISSUE/ REVISION DATE

6-1-16