

GreenWater Laboratories

205 Zeagler Drive
Suite 302
Palatka FL 32177
Ph (386) 328-0882
Fax (386) 328-9646

Contact:

markaubel@greenwaterlab.com
amandafoss@greenwaterlab.com

**Adya Filtration System****MICROCYSTIN RESULTS**

Tested on: 8/13/2014
Method: Enzyme-Linked ImmunoSorbent Assay (ELISA)
Analyte: Microcystins
Analyzed by: Alicia Carter

Sample ID	Initial Conc. Factor	Dilution Ratio	Assay Value, ug/L	Final Dilution Factor	Avg. LFB Recovery(%)	Final Concentration (ug/L)	Average (ug/L)
Pre Filtration-10 ppb MC-LR solution	1x	1:10	1.07	10	102%	10.7	10.8
	1x	1:10	1.09	10		10.9	
Post Filtration-10 ppb MC-LR solution	1x	none	0.01	1	102%	<0.15	ND
	1x	none	0.02	1		<0.15	

ND = Not detected above LOD/LOQ
LOD/LOQ = 0.15 µg/L
LFB = 1.0 µg/L MCLR

Submitted by:

Amanda Foss, M.S.
8/13/2014

Date: