# memo NFC

Digital time switch: User Manual







# Index

	Technical features Safety warnings	page page	3
	Dimensions	page	4 5
	Wiring diagrams	page	
	Display and keyboard description	page	6 7
Н	Initial operation	page	
	Start page (or main)	page	8
	Menu description	page	11
	Settings menu	page	12
	Language setting menu	page	13
	Date setting menu	page	14
	Time setting menu	page	15
	Daylight saving time (DST)/winter time (CET)		
	change setting menu	page	16
	Random switchings setting menu	page	18
	Protection PIN setting menu	page	19
	Program menu	page	20
	Program menu: new	page	25
	Program menu: new daily timed	page	26
	Program menu: new weekly timed	page	27
	Program menu: new yearly timed	page	28
	Program menu: new holiday timed	page	30
	Program menu: check	page	32
	Program menu: modify	page	34
	Program menu: copy	page	36
	Program menu: delete	page	37

NFC menu	page	3
Hour couter menu	page	4
Reset menu	page	4
Firmware menu	page	4
Error signals	page	4
Battery management	page	4
Reference standards	page	4

e 37 - 1 -User manual memo NFC

#### **USER MANUAL**

The digital time switches of memo series are electronic devices for the management of the electrical utilities over time. They allow the time programming (periodicity: daily, weekly or yearly) and have a NFC interface that allows it to be coupled with mobile devices (smartphone or tablet).

Thanks to the free app that can be downloaded from Google Play store, it is possible to program and make settings directly on your smartphone and then transfer all the data to the time switch.

The reverse procedure is also possible, i.e. to copy the programming of a time switch on your mobile device.

The backup battery allows you to keep the settings even in case of black-out and can be replaced through the cover on the back of the time switch.

The time switches of memo series are devices that perform actions of 1BTU type, intended to operate in environments with III overvoltage category and pollution degree 2 in accordance with EN 60730-1 standard.

Code	Model	Description	Power supply
VE339800	memo DW	Daily/weekly time switch 1 channel with NFC interface	230 V AC
VE339801	memo DW	Daily/weekly time switch 1 channel with NFC interface	115 V AC
VE341400	memo DW2	Daily/weekly time switch 2 channels with NFC interface	230 V AC
VE341401	memo DW2	Daily/weekly time switch 2 channels with NFC interface	115 V AC
VE340600	memo Y	Daily/weekly or yearly time switch 1 channel with NFC interface	230 V AC
VE342200	memo Y2	Daily/weekly or yearly time switch 1 channel with NFC interface	230 V AC

#### **TECHNICAL FEATURES**

- Power supply:
  - 230 Vac (-15% ÷ +10%) 50/60 Hz
  - 115 Vac (-15%  $\div$  +10%) 50/60 Hz (depending on the model, see page 2)
- Power consumption:
  - memo DW, memo Y: 1W (3.5 VA)
  - memo DW2, memo Y2: 1.5W (5.5 VA)
- Lithium backup battery: 3V, CR2032 type (replaceable)
- Output:
  - memo DW, memo Y: 1 monostable change-over relay with maximum switchable load of 16(10)A / 250V
  - memo DW2, memo Y2: 2 monostable change-over relays with maximum switchable load of 16(10)A / 250V


- Display LCD with backlighting (active with AC power supply)
- · NFC communication interface
- · Storable programs:
  - memo DW, memo Y: 120 events
  - memo DW2, memo Y2: 120 events (divisible on 2 channels)
- · Actions type: 1BTU
- Operating temperature: -20 ÷ +50°C
- Operating humidity: 20 ÷ 90% non condensing
- Storage temperature: -25°C ÷ +70°C
- Container: 2 DIN modules
- Protection degree: IP20
- Insulation: reinforced between accessible parts (front) and all the other terminals


# **SAFETY WARNINGS**

- During product installation and operation it is necessary to observe the following instructions:
- The instrument must be installed by a qualified person, strictly in observance of the connection diagrams shown in this manual.
- 2) After installation inaccessibility to the terminals without using dedicated tools must be quaranteed.
- 3) Before accessing the connection terminals, make sure that the leads are not live.
- 4) Do not connect or feed the instrument if any part of it is damaged.
- 5) The product must be installed and activated in compliance with current electric systems standards,
- 6) Do not use the product for anything other than the indicated purpose.
- 7) In the electrical system upstream of the device must be
- installed a protection device against the overcurrents


  8) The product can be used in environments with
- 8) The product can be used in environments with Measurement Category III and Pollution degree 2, according to the Standard EN 60730-1.

#### **DIMENSIONS**






# memo DW, memo Y




# memo DW2, memo Y2



# **DISPLAY AND KEYBOARD DESCRIPTION**



- General indications
- Time indication
  Channel 1/channel
- (3) Channel 1/channel 2 status indication
  - blocked switchings
  - ② active random switchings
  - active holiday program
  - active pulse program
  - active manual program
- Day of the week (DAY) indication



- (5) Turn on the display Access the menu ESC (one level back)
- (§) Key "C1": decrease datum/previous menu/ switching channel 1/ lock channel 1

Key "62": increase datum/next menu/ switching channel 2 / lock channel 2

- ⑦ Confirm selection
- Hardware reset

Key "**Ok**" + "**C1**" (3 sec): random switching channel 1 Key "**Ok**" + "**C2**" (3 sec): random switching channel 2


# **INITIAL OPERATION**

- Once out of the package, memo is off: press the key and wait a moment before activating the display
- The set language is Italian. To change it, press the key I for at least 3 seconds. Choose among: Italian, English, Spanish, French or German and confirm with I
- Make connections following the diagrams on page 5 of this manual
- · Power memo: the backlighting turns on permanently
- The presence of the backup battery allows the memo to have updated date and time.

To make the other settings follow the following steps:

Date	- format: DD/MM/YY - 1st day of the week: Monday
Daylight Saving time (DST) change: active	- start of daylight saving time (DST): last Sunday of March at 02:00 o'clock - end of daylight saving time (DST): last Sunday of October at 03:00 o'clock
Random switchings:	- minimum: 1 minute - maximum: 5 minutes
Keyboard lock with PIN:	disabled ()
NFC interface	active


# **START PAGE (or main)**





- day of the week
- product identification code and serial number
- battery status (only if discharged)
- -NO SUPPLY\*
- · Press the key
- to access the menu of memo


[3] and [32] to change channel 1 and channel 2 status (only for memo DW2, memo Y2)



NOTE: the NFC interface is active only when the memo displays the initial (main) page. The action range of the NFC interface is deliberately limited: in order for the memo and the smartphone to communicate, it is necessary to place the latter on the memo display.

\* Only if memo is not powered by mains.
In this condition the backlighting is not active and the relay is in off status.

# Access the store of your device, install and start the free app memo – Vemer.







- 9 -

- ① At the start the app displays the list of the associated memo devices (both Bluetooth and NFC). To associate a new memo NFC, press the symbol "+" in the upper right corner.
- ② In the "Choose connection type" screen, select NFC.
- 3 Place the smartphone on the display of the memo to be associated.

Note: each device is identified by the product code (for example VE339800) and by the serial number (for example 00000020). These informations can be viewed from the main page of the memo.


Warning: make sure visible that the display shows the main page (initial), Otherwise the NFC interface is not active and the device is not

visible.

Note: from this screen you can create a virtual memo. With a virtual memo you can create programs even if you do not have a memo available. The programming and settings of the virtual memo can be saved in the app and then transferred to the memo.

- The app shows the detected memo: do a tap on the memo to complete the association. Once the procedure is complete, the memo is added to the list of associated devices.
  Select the memo on which to act from the list of associated devices.
- ⑤ The app displays the initial page of the selected memo. From this page you can:
  - a. Create new programs that will then be copied to the memo
  - b. View the parameters and associate an alias (name that identifies the time switch, such as "memo DW Belluno") to the memo


# **MENU DESCRIPTION**




(6) "Ver FW" menu allows you to check the firmware version installed on the device.

# **SETTINGS MENU**


- "Settings" menu allows you to view and eventually to modify the general operation settings of memo, such as:
- 1 language
- 2 date
- ③ time
- (4) automatic daylight saving time (DST) change
- ⑤ position (astronomical coordinates)
- **(6)** interval duration between two random switchings
- keys protection by PIN



# Language setting menu




#### **Date setting menu**



- month-day-year ( MM / 심급 / 남당 ).
- 2 Choose, by convention, the first day of the week. In Italy, for example, the first day of the week is Monday, in the UK it's Sunday.
- 3 Enter the date: day, month, year.

#### Time setting menu



#### Parameters modification

Set the time: hours, minutes.

#### Daylight saving time (DST)/winter time (CET) change setting menu

Daylight saving time (DST)/winter time(CET) change and vice versa can occur in an automatic way. In this case, memo:

- increases by an hour in the passage from winter time (CET) to daylight saving time (DST)
- decreases by an hour in the passage from daylight saving time (DST) to winter time (CET)

For every change it's necessary to specify:



the week of the month during which the time change occurs (first, second, third, fourth, last)



the day of the week (Monday: 1, Tuesday: 2, ...)




the month




the hour and the minutes

In Italy,for example, daylight saving time (DST) begins occurs the last (LRSE) Sunday (7) of March (DB) at D2:00 o'clock, and ends the last (LRSE) Sunday (7) of October (D) at D3:00 o'clock.



- ① Choose to activate (AUE) □N) or to disable (AUE) □FF) the automatic time change.
- ② Set date and time of the winter time (CET) daylight saving time (DST) change.
- ③ Set date and time of the daylight saving time (DST) winter time (CET) change.

#### **Random switchings setting menu**



The "random switching  $\odot$ " function (activated with the combination described on page 6) allows the channel on which it's active to automatically switch and at random time intervals.


In this menu it's possible to define the minimum and maximum duration of the time interval between two random switchings. Default minimum duration is 1 minute, maximum duration is 5 minutes.

#### Parameters modification

- ① Set the minimum duration. It's possible to set values between 1 minute and the *maximum duration*.
- ② Set the maximum duration. It's possible to set values between the *minimum duration* and 23:59 hours.

Note: setting the minimum duration equal to the maximum, the switchings will occur at fixed time intervals.

#### **Protection PIN setting menu**



The protection code (PIN) is used to lock the keyboard and prevent changes by unauthorized persons. With active PIN protection, pressing any key, it's necessary to enter the PIN: if PIN is correct the keyboard unlocks; after 3 minutes without pressing a key, the keyboard will lock automatically.

#### To activate PIN protection:

- set a value between 000 and 999

#### To disable PIN protection:


- set "---" (located before 000 or after 999)

Note: If you have forgotten your PIN code to unlock memo it's necessary to carry out a hardware reset (see page 42).

# **PROGRAM MENU**

The menu "program" allows you to:


- ① create a new program
- ② check created programs
- 3 change or delete a created program
- (4) copy all created programs of channel 1 on channel 2 and vice versa (only for memo DW2, memo Y2)
- (5) delete all programs of a channel



# Select days

scroll through the days of the week from 1 to 7:

- by pressing the key 22 to move to the next day without selecting the current day
- by pressing the key ok to select/deselect the current day and move to the next



#### Programs types

- ON/OFF program: is composed of a switching of the ON relay and of a subsequent switching of the OFF relay. It can have a daily period
  (everyday with the same modes), weekly (every week with the same modes), yearly (all the years with the same modes. Available only on
  memo Y and memo Y2).
- PULSE ON program: is an ON relay switching for a maximum duration of 59 seconds. It can have a daily period (everyday with the same modes), weekly (every week with the same modes), yearly (all the years with the same modes. Available only on memo Y and memo Y2).
- PULSE OFF program: is a relay switching OFF for a maximum duration of 59 seconds. It can have daily period (everyday with the same modes), weekly (every week with the same modes), yearly (all the years with the same modes. Available only on memo Y and memo Y2).
- HOLIDAY program: is a period of time defined by a start time and an end time within which all programmed switchings (of that channel)
  are disabled. The relay is in OFF position (OFF holiday) or in ON position (ON holiday).

Important: on the same channel can't coexist ON pulses and OFF pulses (if an ON pulse is already present, it's not possible to save a holiday OFF and vice versa).

Important: on the same channel can't coexist holiday ON programs and holiday OFF programs (if a holiday ON program is already present, it's not possible to save a holiday OFF program and vice versa).

# **Programs priority**


The priority programs defines how memo manages the case in which programs with different period are running at the same time (1 indicates higher priority).

Program	Date* (specific year)	Yearly (specific month, every year)	Monthly (every month, every year)	Weekly	Daily
Holiday	1				
Pulse	2	3	4	5	6
On/Off	7	8	9	10	11

<sup>\*</sup> Date: select day, month, year (program carried "only once in the life of the product"). If the month is not specified, the program is carried out all days xx of all months of the specified year.

#### Priority list on/off

In case in which, on the same channel, on/off programs are provided with different period (daily, weekly or yearly) to carry out in the same day, only the program with the highest priority is executed.



From this example it's possible to see that the daily event on Monday is not carried out because in the same day it is provided the beginning of the week program (even if the daily program

of Monday begins and ends before the beginning of the weekly program). Instead, the daily program of Sunday is carried out because it's the only one running for that day.


# **Holiday program**

The holiday program just begins and ends exactly at the specified times.










① Choose the channel to program (only for memo DW2 and memo Y2)

# Program menu: new daily timed



# **Program parameters**

- on/off: on time and off time
- on pulse: time and pulse duration (max 59 seconds)
- off pulse: time and pulse duration (max 59 seconds)

- 26 -

# Program menu: new weekly timed F IMER MEEKL 4 OFF 88 ILY Enter program parameters F IWE9 F IME9 JPULSE OFF ESC < C1 C2

ОК


C1 C2

# Program parameters

- on/off: day (or days)\* and on time, day (or days) and off time
- on pulse: day (or days)\* and pulse time, pulse duration (max 59 seconds)
- off pulse: day (or days)\* and pulse time, pulse duration (max 59 seconds)

<sup>\*</sup> See "Days selection" on page 21

# Program menu: new yearly timed



#### **Program parameters**

- on / off: day (or days) \* and on time, day (or days) and off time
- on pulse: day (or days) \* and pulse time, pulse duration (max 59 seconds)
- off pulse: day (or days) \* and pulse time, pulse duration (max 59 seconds)

<sup>\*</sup> see "How to choose the day (or days) in a yearly program" on p. 29 - 28 -

How to choose the day (or days) in a holiday program



1 to set the program:

in the first, second, third, fourth or last week of the month in the day/s (Monday, ...) of the week just specified the specified month ( MM for all months) the given year ( 44 for all vears)

Nota: in this case, the yearly program must begin and end in the same day. Otherwise ERROR  $\Box$   $\Box$   $\Box$  is signaled.

2 to set the program on the last day:

--- / MM / 99 of all months of all years

---/VV/39 of the specified VV month of all years

---/MM/ZZ of all months of the specified ZZ year

----/VV / ZZ of the specified VV month of the specified ZZ year

3 to set the program on the day XX (1,2,3...):


xx/MM/99 of all months of all years

××/VV/99 of the specified VV month of all years

××/MM/ZZ of all months of the specified ZZ year

 $\times\times / VV / ZZ$  of the specified VV month of the specified ZZ year

# Program menu: new holiday time



- ① HOLIDAY OFF: the relay is OFF from the beginning to the end of holiday program.
- $\ensuremath{@}$  HOLIDAY ON: the relay is ON from the beginning to the end of holiday program.

# **Program parameters**

- beginning of the program
- end of the program

- 30 -User manual memo NFC How to choose the day (or days) in a holiday astro program



1 to set the program:

in the first, second, third, fourth or last week of the month in the day/s (Monday, ...) of the week just specified the specified month ( MM for all months) the given year ( 444 for all years)

Note: in this case, the holiday program must begin and end in the same day. Otherwise ERR이유 이 네이s signaled.

(2) to set the program on the last day:

--- / MM / 99 of all months of all years

--- /VV / 44 of the specified VV month of all years

---/MM/ZZ of all months of the specified ZZ year

---/VV / ZZ of the specified VV month of the specified ZZ year

3 to set the program on the day XX (1,2,3...):


xx/MM/99 of all months of all years

x x / V V / 뇌님 of the specified VV month of all years

x x / MM / Z Z of all months of the specified ZZ year

 $\times\times / VV / ZZ$  of the specified VV month of the specified ZZ year

#### Program menu: check




# How to check a program

- ① choose the channel (only for memo DW2, memo Y2)
- ② choose the period: daily, weekly, yearly, holiday
- 3 choose the type: on/off, on pulse, off pulse


Note: a program requires more screens to be displayed:

- press the key ox to move from the first to the second part of the same program
- press the keys C1 and C2 to switch from one program to another



- 33 -User manual memo NEC

# **Program menu: modify**



# How to modify or to delete a program


- ① choose the channel (only for memo DW2, memo Y2).
- 2 choose the period: daily, weekly, yearly, holiday
- 3 choose the type: on/off, on pulse, off pulse

Note: a program requires more screens to be displayed:


- press the key or to move from the first to the second part of the same program
- press the keys Cland C2 key to switch from one program to another

To modify: press for a long time (at least 3 seconds) the key ok

To delete: press for a long time and simultaneously the keys ok and -




- 35 -User manual memo NEC



<sup>&</sup>quot;Copy" menu allows copying the programs of a channel (origin channel) on the other channel (channels destination). Note: the programs previously stored on the channel destination will be deleted.

### Program menu: delete



<sup>&</sup>quot;Delete" menu is used to delete all stored programs on the specified channel. Note: to delete one single program to see "modify" mode (see page 34).

# **NFC MENU**

The NFC menu allows you to enable or disable the NFC interface.

#### To enable the NFC interface:

1 set NFC ON

Warning: to make the NFC interface active, the memo must displays the main page (see page 8).

The NFC interface is therefore not active when browsing through the memo NFC menus.


To guarantee a stable communication, lay the smartphone on memo's display.

### To disable the NFC interface:

2 set NFC OFF

In this way no communication can take place between your device and memo.

The memo works with the settings and programs already set; any changes or creation of new programs must be made by acting directly on the keyboard of memo.



# **HOUR COUNTER MENU**


"Hour counter" menu allows you to display the hours of use (relay on) of connected loads.

The maximum value of the counter is 99999 hours (about 11 years); reached the maximum limit, the counter resets automatically.

### To reset a counter:

- 1. select the desired channel (only for memo DW2 and memo Y2)
- 2. press the key of for 3 seconds until the display shows "H□UR ENE dELEEE ②"
- 3. confirm by pressing ok (press to exit without zeroing)

Note: it's possible to reset all counters contemporary from the "Reset" menu (see page 42).



# **RESET MENU**

"Reset" menu allows you to restore the initial state of the device.

#### Available resets:

- ① Settings reset: deletes all the carried out settings (except the language and the PIN)
- ② Time programs reset: deletes all saved time programs
- 3 Holiday programs reset: deletes all saved holiday programs
- ④ Counter reset: resets the counters of all channels
- ⑤ Reset all: carries out all the above described resets and deletes the language and PIN protection


There is also another reset, of hardware type, which allows you to reset the device in case it responds to the pressing of the keys so unexpectedly, without losing the carried out settings/programs (only the date and the time are lost).

To carry out a hardware reset:

1. press the key "R" with a sharp object



The hardware reset is also useful when you forget PIN protection. Reset, in fact, unlocks the keyboard for 3 minutes, the necessary time to access the appropriate menu and check/disable PIN.




- 43 -User manual memo NFC

# **FIRMWARE MENU**

This menu shows the firmware installed in the device, where: 022 is the revision index

05 is the month

20 is the day



## **ERROR SIGNALS**

When s	etting up	programs,	in case	of a	discrepancy,	the 1	following
error m	essages	can occur:					

ERROR DO I on and off events with different frequency (each on event must have an off event)

ERROR 002 on and off concomitant events of the same program

ERROR DD3 Two or more consecutive on events of the same program / Two or more consecutive off events of the same program

ERROR 004 Invalid date

ERROR 005 Insufficient memory

ERROR 006 Attempt to set an on pulse on a channel where is already stored an off pulse (see page 25)

ERROR 007 Attempt to set an off pulse on a channel where is already stored an on impulse (see page 25)

ERROR 008 Attempt to set an on holiday program on a channel where is already stored an off holiday program (see page 30)

ERROR DD9 Attempt to set a holiday off program on a channel where a holiday on program is already stored (see page 30)

ERROR O ID Attempt to set a holiday program of on and off events on different days of the week (see page 31)

ERROR 030 Error accessing memory \*

\* In this case, carry out a hardware reset (see page 42). If the error persists, contact Vemer technical support (assistenza.tecnica@vemer.it).

## **BATTERY MANAGEMENT**

When the battery is close to empty, on the first line of the display appears b유난도유및. In this case, the battery must be replaced as soon as possible. **Use only batteries of CR2032.** 

- To replace the battery:
- disconnect the mains
- remove the battery slot cover, turning it anti-clockwise
- replace the battery and remount the cover, turning it clockwise
- connect the power supply

**Warning:** do not use metal objects (such as screwdrivers) to remove the battery because this may cause the power reserve to be canceled, resulting in a loss of date and time.

**Warning:** in order not to lose the programming steps and carried out settings, it is necessary to ensure that the time for the battery replacement doesn't exceed 60 seconds (in absence of power by means).

It is necessary to remove the batteries before the instrument is scrapped.

⚠

In case of replacement, dispose of the batteries in the appropriate places separate waste collection containers



### REFERENCE STANDARDS

### EU CONFORMITY DECLARATION

Vemer declares that the device complies with the EU directive 2014/53/EU (RED) with reference to the following standards:

- EN 60730-2-7 ETSI EN 301 489-1
- ETSI EN 301 489-3
   ETSI EN 300 330

The complete text of EU conformity declaration is available at the Internet address www.vemer.it.



information to users pursuant to art. 14 of the directive 2012/19 / EU of the european parliament and of the council of 4 july 2012 on waste electrical and electronic equipment (WEEE)

If the crossed-out bin symbol appears on the equipment or packaging, this means the product must not be included with other general waste at the end of its working life.

The user must take the worn product to a sorted waste center, or return it to the retailer when purchasing a new one.

Products for disposal can be consigned free of charge (without any new purchase obligation) to retailers with a sales area of at least 400 m<sup>2</sup>, if they measure less than 25 cm.

An efficient sorted waste collection for the environmentally friendly disposal of the used device, or its subsequent recycling, helps avoid the potential negative effects on the environment and people's health, and encourages the re-use and/or recycling of the construction materials.



# Vemer S.p.A.

I - 32032 Feltre (BL) • Via Camp Lonc, 16 e-mail: info@vemer.it - web site: www.vemer.it