

**Overall EN 12209:2016 Classification Attained\*.**

1	2	3	4	5	6	7	8
Category of use	Durability and force on latch	Door mass and closing force	Fire	Safety	Corrosion and temperature resistance	Security and drill resistance	Key identification
2	M	4	0	0	F	7	-

**Overall BS 3621:2017 Classification Attained\*.**

With key / key cylinder

Pass

\* The following were not evaluated:  
BS 3621 6.1, General vulnerability of lock assembly.

**Overall BS 8621:2017 Classification Attained\*.**

With thumbturn cylinder

Pass

\* The following were not evaluated:  
BS 8621 6.1, General vulnerability of lock assembly.

Report authorised by:



Dr Martin White

Date: 30 September 2019

Director

**REPORT ENDS**