



UL/FM Listing Information:

- **Our MICtreat® FPS System components are UL Listed, however, per NFPA 13 our MICtreat® FPS Chemical does not require UL/FM Listing**
- **MICtreat® FPS Chemical is EPA registered and approved for use in FPS**
- **MICtreat® FPS Chemical does meet all NFPA 13 requirements**

See NFPA 13 2019 references below:

NFPA 13, 2019 Edition states in Section 7.8.1 "Additives to the water supply intended for control of microbiological or other corrosion shall be listed for use within fire sprinkler systems."

The definition of "listed" in Section 3.2.3 states "Equipment, materials, or services included in a list published by an organization that is acceptable to the authority having jurisdiction and concerned with the valuation of products or services, that maintains periodic inspection of production of listed equipment, or materials, or periodic evaluation of services, and who's listing states that either the equipment, material, or service meets appropriate designated standards or has been tested and found suitable for a specified purpose."

The NFPA confirms the interpretation of these Sections to simply mean that products must be approved for use in fire protection and that no specific UL/FM Listing is required. Our MICtreat® FPS Chemical does meet this requirement as it is EPA registered and approved for use in FPS.