




96-D Allen Boulevard
 Farmingdale, New York 11735-5626 USA
 Tel. +1 (631) 293-8944 Fax +1 (631) 293-8956
 e-mail: testing@govmark.com

Page 2

Received:09/01/2015	Completed:09/15/2015	Letter: P	CT	P.O.#:	Test Report #:	3-09555-0-
Client's Identification	Product Description: Photo Tex Self-Adhesive.					
Tested For: Walter Gierlach	Photo Tex Group Inc. 4030 Simon Road Boardman, OH 44512			Key Test: ASTM E 84 (BLDG)	1185	
				Tel: 1-(330)-783-0083	Ext:	
				Fax: 1-(330)-783-0761		
RESULTS:						
Flame Spread Index: 15						
Smoke Developed: 15						
CONCLUSION: Based on the above Results and Code Classification System the item tested is assigned a:						
<input checked="" type="checkbox"/> Class I or A rating <input type="checkbox"/> Class II or B rating <input type="checkbox"/> Class III or C rating <input type="checkbox"/> Fails to achieve a minimum classification thereby rendering the product unsuitable in terms of code requirement						
DATA SUMMARY:						
Time to Ignition: 00.10 minutes						
Maximum Flame Spread "Distance": 03.49 feet						
Maximum Flame Spread "Time": 01.40 minutes						
CODE CLASSIFICATION SYSTEM:						
	Flame Spread Index	Smoke Developed				
	-----	-----				
Class I or A:	0 - 25	450 or less				
Class II or B:	26 - 75	450 or less				
Class III or C:	76 - 200	450 or less				
BUILDING CODE CITATION FOR THE CLASSIFICATION SCHEME (See "DISCUSSION" on Page 3):						
(1) 2015 edition, NFPA 101 Life Safety Code, para. 10.2.3.4						
(2) 2015 edition, NFPA 5000 Building Construction & Safety Code, para. 10.4.2						
(3) 2015 edition, International Building Code, para. 803.1.1						
CERTIFICATION: I certify that the above results were obtained after testing specimens in accordance with the procedures and equipment specified above.						
AUTHORIZED SIGNATURE GOVMARK /bg CT /pm			 Robert I. Brown SEP 18 2015			
(Page 2 of 3)						

File Copy