

WALL

GENERAL PRODUCT INFORMATION:

These fixtures are intended to be installed utilizing NEC compliant junction boxes.



Use approximate 2x4 single gang junction box or provided goof plate to completely cover the junction box.

This product is suitable for damp locations.

This product can be dimmed with most ELV or TRIAC dimmers.

This instruction shows a typical installation.

CAUTION - RISK OF FIRE

This product must be installed in accordance with the applicable installation code by a person familiar with the construction and operation of the product and the hazards involved.


Use minimum 90°c supply conductors.

TECH LIGHTING


7400 Linder Ave, Skokie, IL 60077 847.410.4400

www.techlighting.com

© 2020 Tech Lighting, L.L.C. All rights reserved. Visual Comfort Group



Install the Fixture



- 1 With the provided Allen wrench, remove the Allen screws on the fixture base.
- Remove the mounting plate from the fixture base
- Connect the black/blue driver wire to the black/blue fixture wire with a wire nut.
- Connect the red driver wire to the red fixture wire with a wire nut.
- 5 Connect the fixture to a suitable ground in accordance with local electrical codes.
- 6 Connect the white driver wire to the neutral power line with a wire nut.
- 7 Connect the black driver wire to the hot power line with a wire nut.
- For 277V Only: Connect the purple and gray wires to a compatible dimmer. If not using 0-10V dimming, cap off the purple and gray wires.
- Properly place the driver, all wires, and wire nut connections into the junction box, and install the mounting plate to the junction box with the two #6-32 screws provided. NOTE: Must use approximate 2x4 junction box or goof plate to completely cover the junction box.
- 10 Mount the fixture base onto the mounting plate, and secure it in place by reinstalling the Allen screws using the provided Allen wrench.