
Notes:

- 1. This drawing is for 'Dimensional Information' only. It is essential that this drawing is read in conjunction with the 'Installation Guidelines' supplied with the unit.
 All pipe connections are Ø110mm PVCu.
- Additional ventalation can be achieved on the incoming drain, via a stack pipe. Position to suit specific site conditions.
- Confirm with local building regulations if additional venting is required.
- Tank has a trimmable Inlet Invert from 0.5m to 1.0m. Neck can be trimmed at 100mm increments to required Invert. Refer to Drawing DS1261P.
- Keys supplied to open the pedestrian duty cover latches.
 **Pea-Shingle backfill is reliant on use of correct strapping and anchorina.
- Rodding access to be extended to ground level and suitable cover fitted (by others).

Tank Dimensional Table													
Unit	Storage Volume (Ltr)	Dim 'A' (mm)	Dim 'B' (mm)	Dim 'C' (mm)	Dim 'D' (mm)	Dim 'E' (mm)	Dim 'F' (mm)	Dim 'G' (mm)	Dim 'H' (mm)	Tank Weight			
GST028SzGK	2800	500-1000	1255	550-1050	1205	2480	1130	1450	390	240 Kgs			
GST035SzGK	3500	500-1000	1255	550-1050	1205	3000	1180	1450	390	270 Kgs			
GST040SzGK	4000	500-1000	1255	550-1050	1205	3360	1215	1450	390	300 Kgs			

Strapping Positions									
Unit	1	2	3	4					
GST028TzGK	315mm	460mm	460mm	315mm					
GST035TzGK	315mm	800mm	800mm	315mm					
GST040TzGK	315mm	900mm	900mm	315mm					



Material: Various

Weight: 127.02 Kg Kgs

Please check with Kingspan Environmental that this drawing is the latest issue Date Drawn by Approved by Description 04 30.05.19 CC1482 - Pictorial Update to Inlet & Outlet Pipework T.Kelly 03 29/03/17 JMcM CC1375

Kingspan Environmental reserve the

GAMMA Sales Drawing - S.Stage, Gravity

Drawina: DS1267P

All dimensions in mm Scale: Not to scale

Z:\Drawing Data\02 - Sales Drawings\DS\DS - 12\DS1267P

right to alter the details of this drawing without prior notice. This drawing is copyright and may not be reproduced or used without the written permission of Kingspan Environmental.

Tolerance:

Thickness: n/a

Surface Area:



Page 1 of 1