

Breathable Air Grade D Compliance

Compliance with OSHA Standard 29 CFR 1019.34 Grade D

Unipipe® pipes, fittings and valves can be installed in systems that meet the requirements of the OSHA Standard 29 CFR 1019.134 Grade D according to the following directions:

- 1. After the end of the pipeline assembly operations, a perfect cleaning purge must be done.
- 2. A check of the quality of the air must be done, in any case, through proper instruments before to put the system in service.
- 3. The constant monitoring of air quality is, however, advisable to prevent any possible contamination caused by equipment faults, lack of maintenance, equipment breakdowns, etc.

Unipipe® systems cannot take the place of any filtering/purification systems. The pipeline will only maintain the air quality obtained by filters, separators, dryers and other air treatment equipment supplied from third parties.