




Report For: Canadian Guardians
505 Apple Creek Boulevard, Unit #4
Markham, Ontario
L3R 5B1
Phone: 647-808-6308
Email: kleung@canadianguardians.com
management@venturesolutionscorp.ca

Laboratory #: 853368-21
Report Date: January 15, 2021
Received Date: January 11, 2021

Attention: Kei Leung/Jennifer Shen
Specimen: #1: Face mask-202006

TEST REPORT

One specimen, consisting of face masks, was submitted to be tested for synthetic blood penetration to determine acceptability with level barrier classification under ASTM F2100-19 requirements as well as Bacterial Filtration Efficiency, Differential Pressure, Particle Filtration Efficiency and Flame Spread, which were previously tested under Laboratory Number 850550-20.



Revision: Results for Bacterial Filtration Efficiency, Differential Pressure, Particle Filtration Efficiency and Flame Spread, represented by Laboratory Number 850550-20, were added to this report.
Revision Date: January 15, 2021

This report is subject to the following terms and conditions: 1. This report relates only to the specimen provided and there is no representation or warranty that it applies to similar substances or materials or the bulk of which the specimen is a part. 2. The content of this report is for the information of the customer identified above only and it shall not be reprinted, published or disclosed to any other party except in full. Prior written consent from Cambridge Materials Testing Limited is required. 3. The name Cambridge Materials Testing Limited shall not be used in connection with the specimen reported on or any substance or materials similar to that specimen without the prior written consent of Cambridge Materials Testing Limited. 4. Neither Cambridge Materials Testing Limited nor any of its employees shall be responsible or held liable for any claims, loss or damages arising in consequence of reliance on this report or any default, error or omission in its preparation or the tests conducted. 5. Specimens are retained 6 months, test reports and test data are retained 7 years from date of final test report and then disposed of, unless instructed otherwise in writing. 6. When making a statement of conformity to a specification or standard the report will make the statement of conformity based on the absolute value of the test result. Test Report Template Revision August 20, 2019

Per Steve Brown
Authorized By Stephen Brown
Per Anamaria Rojas Pineda
Technician, Anamaria Rojas-Pineda



Medical Face Mask Material Requirements

Characteristic	Level 1 Barrier	Level 2 Barrier	Level 3 Barrier	Summary Results
Bacterial Filtration Efficiency, %	≥95	≥98	≥98	Pass Any Level ¹
Differential Pressure, mm H ₂ O/cm ²	<5.0	<6.0	<6.0	Pass Any Level ²
Sub-Micron Particulate Filtration Efficiency at 0.1 micron, %	≥95	≥98	≥98	Pass Any Level ³
Synthetic Blood Penetration minimum pressure in mmHg for pass result	80	120	160	Pass Level 3
Flame Spread	Class 1	Class 1	Class 1	Pass Any Level ⁴
OVERALL PERFORMANCE LEVEL	Complete – Level 3			

¹Note: Results for Bacterial Filtration Efficiency are represented by Laboratory Number 850550-C-20.

²Note: Results for Differential Pressure are represented by Laboratory Number 850550-B-20.

³Note: Results for Particle Filtration Efficiency are represented by Laboratory Number 850550-D-20.

⁴Note: Results for Flame Spread are represented by Laboratory Number 850550-E-20.



Laboratory # 853368-21
REVISED
Canadian Guardians

SYNTHETIC BLOOD PENETRATION

ASTM F1862/F1862M-17 at 160 mmHg pressure

RESULTS

Specimen #	Test Pressure (mmHg)	Total Number of Specimens	Number of Pass Specimens	FINAL RESULT
1	160	32	31	Pass for Level 3

Note: Acceptable Quality Limit of 4.0% is met for single sampling plan when 29 or more of the 32 tested specimens show pass results.

Material construction type	Not provided / unknown
Supplier	Canadian Guardians
Lot number	Not provided/unknown
Date of receipt	January 11, 2021
Date of test	January 14, 2021
Fluid velocity (cm/s)	638
Volume of impact fluid (ml)	2
Angle of pneumatic valve to horizontal	2°
Description target area mask	Outside Blue ripple area
Distance from tip cannula to mask (in)	12
Technique to enhance visual detection	Cotton swab used to lightly daub on the inside surface
Conditioning parameters	21±5°C, 85±5% R.H for minimum of 4 hours



BACTERIAL FILTRATION EFFICIENCY

A Bacterial Filtration Efficiency (BFE) test was completed according to the procedure in ASTM F2101-19 to determine the filtration efficiency of test articles by comparing the bacterial control counts upstream of the test article to the bacterial counts recovered downstream. A suspension of *S. aureus* was aerosolized using a nebulizer and delivered to the test article at a constant rate with a target delivery rate of $1.7 \times 10^3 - 3.0 \times 10^3$ colony forming units (CFU) per test article with a mean particle size of $3.0 \pm 0.3 \mu\text{m}$. The aerosolized suspension was drawn through the test article which was clamped in a six stage Andersen air sampler, at a constant flow rate of 28.3 liters per minute (LPM), for collection on bacteriological agar plates.

Challenge Microbe: *Staphylococcus aureus* ATCC 6538
Test Side: User side facing challenge
Area Tested: $\sim 38.5 \text{ cm}^2$
Flow Rate: 28.3 LPM
Test Article Conditioning: $85 \pm 5\% \text{ RH}$ at $25.0 \pm 0.5^\circ\text{C}$ for a minimum of 4 hours
Challenge Level: $1.7 \times 10^3 \text{ CFU}$
Mean Particle Size: $2.9 \mu\text{m}$

Requirements ASTM F2100-19:
Bacterial filtration efficiency (%)
Level 1 Barrier: ≥ 95
Level 2 Barrier: ≥ 98
Level 3 Barrier: ≥ 98

RESULTS

Specimen #	Total CFU Recovered	Percent BFE (%)	Specimen (Pass/Fail)	FINAL RESULT
1-1	<1	>99.9	Pass	Pass any Level
1-2	1	99.9	Pass	
1-3	1	99.9	Pass	

The filtration efficiency percentages were calculated using the following equation:

$$\% \text{ BFE} = \frac{C - T}{C} \times 100$$

C = Challenge Level
T = Total CFU recovered downstream of test article

Note: Testing performed by GAP EnviroMicrobial Services Ltd., 1020 Hargrrieve Road, Unit 14, London, Ontario, Canada, N6E1P5

Note: Results for BFE are represented by Laboratory Number 850550-C-20.



Laboratory # 853368-21
REVISED
Canadian Guardians

FLAME SPREAD

The specimen, consisting of 5 masks, was tested in accordance to 16 CFR 1610 (1-1-16 Edition).

	Specimen #	RESULT	CONCLUSION
Specimen #1	1-1	IBE	Classified as Class 1 Pass any Level
	1-2	IBE	
	1-3	IBE	
	1-4	IBE	
	1-5	IBE	

IBE: Ignited but extinguished

Test: Flame Resistance 45° angle test. One-Second Flame Impingement.
Type of fabric: Without a raised fiber surface
Surface tested: Face
Type of test: Original State
Direction tested: Length
Testing Conditioning: Specimens conditioned at 105°C for 30 min, then placed in desiccator
Requirements: The flame spread time for textile products without a raised fibre surface must be greater than 3.5 seconds.

Note: For a test plan of 5 specimens, no failure is allowed for an Acceptable Quality Limit of 4.0%.

Note: Results for Flame Spread are represented by Laboratory Number 850550-E-20.



DIFFERENTIAL PRESSURE

EN 14683:2019 edition Annex C

Each specimen was conditioned for 4 hours minimum at 21+/-5 C and 85+/-5 % R.H.

Requirements ASTM F2100-19:

Differential Pressure (mmH₂O/cm²)

Level 1 Barrier: <5.0

Level 2 Barrier: <6.0

Level 3 Barrier: <6.0

RESULTS

<u>Specimen ID</u>	<u>Area ID</u>	<u>Differential Pressure (mmH₂O/cm²)</u>	<u>Specimen Pass/Fail</u>	<u>FINAL RESULT</u>
1-1	1	3.0	Pass	Pass any Level
	2	3.0		
	3	2.8		
	4	3.9		
	5	3.0		
	AVERAGE	3.2		
1-2	1	2.9	Pass	
	2	3.0		
	3	3.0		
	4	2.9		
	5	3.4		
	AVERAGE	3.0		
1-3	1	3.4	Pass	
	2	3.0		
	3	2.9		
	4	2.9		
	5	3.0		
	AVERAGE	3.0		
1-4	1	2.9	Pass	
	2	3.1		
	3	3.2		
	4	2.6		
	5	3.0		
	AVERAGE	3.0		
1-5	1	3.1	Pass	
	2	3.0		
	3	3.5		
	4	3.4		
	5	3.5		
	AVERAGE	3.3		


Mask Surface Area: 25mm diameter (x5 test areas) (4.9 cm²)

Air Flow Rate: 8 L/min

Mask Location Specimen taken from: 5 Areas from each specimen distributed all surface wide

Note: For a test plan of 5 specimens, no failure is allowed for an Acceptable Quality Limit of 4.0%.

Note: Results for Differential Pressure are represented by Laboratory Number 850550-B-20.



Laboratory # 853368-21
REVISED
Canadian Guardians

PARTICLE FILTRATION EFFICIENCY

Particles: Monodispersed polystyrene latex spheres (PSL)
Particles Counter: TSI scanning mobility particle sizer spectrometer 3082 and CPC
Tested as per ASTM F2299, non-neutralized aerosol challenge measured over 3 minutes (test specimen / control counts before and after test specimen and averaged)

Test Side: Inside
Area Tested: 21.7 cm²
Particle Size: 0.1 µm
Laboratory Conditions: 23°C, 38% relative humidity (RH)

Requirements ASTM F2100-19:
Particle filtration efficiency at 0.1 micron (%)
Level 1 Barrier: ≥95
Level 2 Barrier: ≥98
Level 3 Barrier: ≥98

RESULTS

Specimen #	Specimen Counts	Average Control Counts	Filtration Efficiency (%)	Specimen (Pass/Fail)	FINAL RESULT
1-1	200,156	1,259	99	Pass	Pass any Level
1-2	200,366	2,315	99	Pass	
1-3	203,529	2,258	99	Pass	
1-4	218,163	1,833	99	Pass	
1-5	204,421	1,517	99	Pass	

Note: The PFE equipment was outsourced and located at University of Toronto, 223 College Street, Toronto, ON, M5T 1R4.

Note: Results for Particle Filtration Efficiency are represented by Laboratory Number 850550-D-20.



ACH Engineering Inc.

170 Ambassador Drive, Unit#6, Mississauga, ON Canada - L5T 2H9

Direct:- +1-647-406-5721 | Email:- info@ACHengineering.com |
Website:- www.ACHengineering.com

Aiming the best "Quality" - Services & Solutions

Commissioning Report for ISO 8 Cleanroom Testing & Certification

CLIENT: CANADIAN GUARDIAN INC.
SITE LOCATION: 505 APPLE CREEK BLVD
UNIT#4, MARKHAM ON

Document Number: PROJECT#21014

Document Version: R0

Date: 20-FEB-2021



INTRODUCTION

A cleanroom for Canadian Guardian was constructed previously and testing is needed to be performed to certify its ISO 8 classification. This test was performed by ACH Engineering's contractor as per IEST-RP-CC006.3 standard on February 17, 2021 at 505 Apple Creek Blvd Unit 4, Markham ON. For an ISO 8 cleanroom, an air change per hour between 5-48 is required.

RESULTS AND DISCUSSION

Airflows were measured on February 17, 2021 at each of the diffusers in one anteroom and one cleanroom.

Materials Airlock (1 Diffuser)	
Room Area, ft ²	64
Room Height, ft	8'
Room Volume, ft ³	512

Personnel Airlock (1 Diffuser)	
Room Area, ft ²	200
Room Height, ft	8'
Room Volume, ft ³	1600

Cleanroom (19 Diffusers)	
Room Area, ft ²	3000
Room Height, ft	8'
Room Volume, ft ³	24000

Air Flow Test (Material Airlock)

Diffuser (refer to room layout)	CFM
1	135
Total Main Room CFM	135

Air Flow Test (Personnel Airlock)

Diffuser (refer to room layout)	CFM
1	105
Total Main Room CFM	105

Air Flow Test (Cleanroom)

Diffuser	CFM	Diffuser	CFM	Diffuser	CFM	Diffuser	CFM
1	530	6	375	11	401	16	436
2	490	7	431	12	324	17	478
3	516	8	382	13	437	18	490
4	514	9	275	14	343	19	383
5	438	10	381	15	496	-	-
Total Main Room CFM	7737						

Air Change per Hour (ACH)

$$\text{Air Change Per Hour} = \frac{\text{Supply CFM} * 60}{\text{Volume of Room}}$$

	ACH (As per test 03-Mar-2020)
Material Airlock	5
Personnel Airlock	13
Cleanroom	19

According to FS 209E and ISO 14644 classifications guideline and IEST-RP-CC006.3 standard, an ISO 8 (Class 100,000) cleanroom should have an ACH rate from 5 to 48. Both the rooms **PASS** the ISO 8 standard based on the actual reading.

Particle Count Survey

The particle count was tested at 24 locations evenly distributed within the cleanrooms, 3 locations for material airlock and 6 locations for personnel airlocks. The average particle count based on the 24 locations meets the requirement for ISO 8 inside the cleanroom. The limit for amount of particles inside the clean room is 3.5 million and the test results show there were <1 million. This **passes** the particle count test.

	Limit (/m ³)	Actual Average (concn/m ³)	Result
≥0.5 μm Particles in Material Airlock (3 Locations)	3,520,000	196,963.3	PASS

	Limit (/m ³)	Actual Average (concn/m ³)	Result
≥0.5 μm Particles in Personnel Airlock (6 Locations)	3,520,000	817,147	PASS

	Limit (/m ³)	Actual Average (concn/m ³)	Result
≥0.5 µm Particles in Cleanroom (24 Locations)	3,520,000	-Refer Test data	PASS

Pressure Differential Test

A pressure test was performed to see the direction of airflow and to insure the cleanrooms had a positive pressure compared to the outside corridor. All the pressures were positive and **passes** the pressure differential test.

Room "From to To"	" W.C.	Pascals	Remarks
Cleanroom to Material Air lock	+0.027	6.73	N/A
Material Airlock to unclassified	+0.05	12.45	N/A
Cleanroom to Personnel Air lock	+0.026	6.48	N/A
Personnel Airlock to unclassified	+0.1	24.91	N/A

The pressure differential reading showed good movement of air flow throughout the cleanrooms.

HEPA Leak Test

A HEPA filter leak test was performed to see the integrity of the HEPA filters. There was no leak observed. Air volume readings were taken off the diffuser in the room. All HEPA found ok in functionality.



ACH Engineering Inc.

ACH Engineering Inc.

170 Ambassador Drive, Unit#6, Mississauga, ON Canada - L5T 2H9

Direct:- +1-647-406-5721 | Email:- info@ACHengineering.com |

Website:- www.ACHengineering.com

Aiming the best "Quality" – Services & Solutions

CONCLUSIONS & RECOMMENDATIONS

Conclusions

The cleanrooms at Canadian Guardian PASSES the requirement for an ISO 8 Cleanroom. The Air changes were more than the minimum required of 5.

The particle counts were well below the maximum limit for both the cleanrooms. There were no concerns with the leak test of the HEPA filters and the air was flowing in the right direction according to the pressure tests.

Recommendations

To have annual tests to ensure Canadian Guardian meets the ISO 8 requirements.

Chirag Shah P.Eng PMP

President
ACH Engineering Inc.



REFERENCES/APPENDICES

Appendix 1 – Photographs/Notes


Appendix 2 – Site Layout Drawing - Cleanrooms

Appendix 3 – Technical Test Results

Appendix 1:

Photographs/Notes





ACH Engineering Inc.

ACH Engineering Inc.

170 Ambassador Drive, Unit#6, Mississauga, ON Canada - L5T 2H9

Direct:- +1-647-406-5721 | Email:- info@ACHengineering.com |
Website:- www.ACHengineering.com

Aiming the best "Quality" - Services & Solutions





ACH Engineering Inc.

ACH Engineering Inc.

170 Ambassador Drive, Unit#6, Mississauga, ON Canada - L5T 2H9

Direct:- +1-647-406-5721 | Email:- info@ACHengineering.com |


Website:- www.ACHengineering.com

Aiming the best "Quality" - Services & Solutions



Appendix 2:

Layout Drawing for Final Test Lab





ACH Engineering Inc.

170 Ambassador Drive, Unit#6, Mississauga, ON Canada - L5T 2H9

Direct:- +1-647-406-5721 | Email:- info@ACHengineering.com |
Website:- www.ACHengineering.com

Aiming the best "Quality" – Services & Solutions

Appendix 3:

Technical Test Results