




REMOVEABLE ORIFICE PLATE  
150 TWINWALL c/w SEAL  
DIAMETER CALCULATED TO  
SUIT ONSITE DESIGN CRITERIA





Ø450mm ACCESS COVER- CIRCULAR WITH  
INTEGRAL 350mm RESTRICTED ACCESS  
PRODUCT CODE: 450ACCRA




Ø110mm SPIGOT  
Ø160mm SPIGOT

Ø110mm SPIGOT  
Ø160mm SPIGOT  
Ø150mm TWINWALL SOCKET

Ø110mm  
Ø160mm  
SPIGOT BLANKED OFF  
FOR CUTTING ON SITE (TYPICAL BOTH SIDES)




OFCP450 BASE




PRODUCT CODE: OFCP450/1

A	OVERALL HEIGHT	1050
B	INLET PIPE INVERT	730
C	DEPTH TO INLET PIPE SOFFIT	580



PRODUCT CODE: OFCP450/1.5

A	OVERALL HEIGHT	1525
B	INLET PIPE INVERT	1205
C	DEPTH TO INLET PIPE SOFFIT	1055



PRODUCT CODE: AICCP450B/2

A	OVERALL HEIGHT	1980
B	INLET PIPE INVERT	1660
C	DEPTH TO INLET PIPE SOFFIT	1510

**RESTRICTION CAPS & ACCESS COVERS**

**NEW DESIGN & CONSTRUCTION GUIDANCE (DCG)** - THIS HAS EFFECTIVELY SUPERCEDED SFA7 AND STATES THAT ACCESS MUST BE RESTRICTED TO A MAXIMUM OF Ø350mm, ON ANY TYPE D OR E INSPECTION CHAMBER, DEEPER THAN 1000mm FROM COVER LEVEL TO PIPE SOFFIT.

**PLEASE NOTE: ALL OFCP450 MODELS ARE SUPPLIED WITH A 450ACCRA - CIRCULAR SECTION ACCESS COVER, WHICH HAS A RESTRICTED INTERNAL OPENING OF 350mm, TO COMPLY WITH DCG.**

DCG ALSO STATES, THAT A SUITABLE **TEMPORARY COVER** MUST BE INSTALLED TO PREVENT SITE RUBBLE AND DEBRIS ENTERING THE CHAMBER DURING CONSTRUCTION. SO AS THE UNITS ARE SUPPLIED TO SITE WITH COVERS INSTALLED, WE SUGGEST THEY ARE LEFT IN SITU DURING CONSTRUCTION.

- MAXIMUM INSTALLATION DEPTH TO COVER LEVEL**  
 - ADOPTABLE - 2000mm TO SOFFIT OF PIPE  
 - NON-ADOPTABLE - 3000mm OVERALL DEPTH
- COMPLIANCE**  
 - NEW DESIGN & CONSTRUCTION GUIDANCE (DCG)  
 - SEWERS FOR ADOPTION (SFA7) 7TH EDITION  
 - SUITABLE FOR ADOPTABLE AND NON-ADOPTABLE APPLICATIONS  
 - BUILDING REGULATIONS - PART H1

DRAWN BY:-	R.U.	CONTRACT REFERENCE:-	N/A
DRAWN DATE:-	16/12/2020	PRODUCT DESCRIPTION	
APPROVED	D.A.	ORIFLO 450 RANGE	
		PRODUCT CODE	OFCP450
		SCALE	1:5
			REV 2
			SHEET 1 OF 1