

DIMMER TESTING WITH: COBLG15WCCT

DATE: 15.11.19



DIMMER BRAND	DIMMER MODEL	PASS/FAIL	MAX LUX WITH NO DIMMER IN CIRCUIT	MAX LUX LEVEL WITH DIMMER IN CIRCUIT 100%	MIN LUX WITH DIMMER	% WHEN DIMMER ON MINIMUM SETTING	COMMENTS
HPM LEGRAND	EM400A2P	FAIL	510	369	64	17%	UNSTABLE
	EM400A3P	PASS	510	510	45	9%	SMOOTH
	EM400TR	PASS	510	510	64	13%	SMOOTH
	EM700TR	PASS	510	514	76	15%	SMOOTH
	EM250TR	PASS	510	514	54	11%	SMOOTH
PDL	PDL354PBDMBW	PASS	510	519	2	0%	SMOOTH
	PDL354PBDMUN	PASS	510	510	74	15%	SMOOTH
	PDL354RDMLED	PASS	510	525	13	2%	SMOOTH
	PDL624M	PASS	510	525	50	10%	SMOOTH
	PDL654M	PASS	510	525	101	19%	SMOOTH. ONLY DIMS TO 19%
KIWI	K005U	PASS	510	528	0	0%	SMOOTH
GERRARD	MEDM	PASS	510	521	0	0%	SMOOTH