

DIMMER TESTING WITH: ICDLR10W

DATE: 13.11.19



DIMMER BRAND	DIMMER MODEL	PASS/FAIL	MAX LUX WITH NO DIMMER IN CIRCUIT	MAX LUX LEVEL WITH DIMMER IN CIRCUIT 100%	MIN LUX WITH DIMMER	% WHEN DIMMER ON MINIMUM SETTING	COMMENTS
HPM LEGRAND	EM400A2P	FAIL	85.2	57.4	9.8	17%	NOT STABLE
	EM400A3P	PASS	85.2	81.2	6.7	8%	SMOOTH
	EM400TR	PASS	85.2	81.2	8.8	11%	SMOOTH
	EM700TR	PASS	85.2	81.8	11.5	14%	SMOOTH
	EM250TR	PASS	85.2	81.6	8.1	10%	SMOOTH
PDL	PDL354PBDMBW	PASS	85.2	84	0.08	0%	SMOOTH
	PDL354PBDMUN	PASS	85.2	82.5	11.5	14%	SMOOTH
	PDL354RDMLEL	PASS	85.2	83	1	1%	SMOOTH
	PDL624M	PASS	85.2	82.8	7	8%	SMOOTH
	PDL654M	PASS	85.2	83.5	14.7	18%	SMOOTH. ONLY DIMS TO 18%
KIWI	K005U	PASS	85.2	83.4	0	0%	SMOOTH
GERRARD	MEDM	PASS	85.2	82.4	0	0%	SMOOTH

DIMMER TESTING WITH: ICDLR40W

DATE: 15.11.19

DIMMER BRAND	DIMMER MODEL	PASS/FAIL	MAX LUX WITH NO DIMMER IN CIRCUIT	MAX LUX LEVEL WITH DIMMER IN CIRCUIT 100%	MIN LUX WITH DIMMER	% WHEN DIMMER ON MINIMUM SETTING	COMMENTS
HPM LEGRAND	EM400A2P	FAIL					UNSTABLE
	EM400A3P	PASS	426	426	8	2%	SMOOTH
	EM400TR	PASS	426	423	17	4%	SMOOTH
	EM700TR	PASS	426	422	23	5%	SMOOTH
	EM250TR	PASS	426	422	13	3%	SMOOTH
PDL	PDL354PBDMBW	PASS	426	426	0	0%	SMOOTH
	PDL354PBDMUN	PASS	426	425	27	6%	SMOOTH
	PDL354RDMLEL	PASS	426	425	1	0%	SMOOTH
	PDL624M	PASS	426	427	11	3%	SMOOTH
	PDL654M	PASS	426	426	43	10%	SMOOTH
KIWI	K005U	PASS	426	426	0	0%	SMOOTH
GERRARD	MEDM	PASS	426	424	0	0%	SMOOTH