

**DIMMER TESTING WITH: LEDMODULE-L**

DATE: 15.7.20

DIMMER BRAND	DIMMER MODEL	PASS/FAIL	MAX LUX WITH NO DIMMER IN CIRCUIT	MAX LUX LEVEL WITH DIMMER IN CIRCUIT 100%	MIN LUX WITH DIMMER	% WHEN DIMMER ON MINIMUM SETTING	COMMENTS
HPM LEGRAND	EM400A2P	FAIL	1215	142	7	5%	UNSTABLE
	EM400A3P	PASS	1215	1098	3	0%	SMOOTH
	EM400TR	PASS	1215	678	12	2%	SMOOTH
	EM700TR	FAIL	1215	1010	276	27%	POOR RANGE
	EM250TR	PASS	1215	845	7	1%	SMOOTH
PDL	PDL354PDBMBW	PASS	1215	1205	0	0%	SMOOTH
	PDL354PDBMUN	PASS	1215	723	52	7%	SMOOTH
	PDL354RDMLED	PASS	1215	811	3	0%	SMOOTH
	PDL624M	PASS	1215	783	3	0%	SMOOTH
	PDL654M	PASS	1215	852	4	0%	SMOOTH
KIWI	K005U	PASS	1215	983	29	3%	SMOOTH
GERRARD	MEDM	PASS	1215	830	7	1%	SMOOTH

**DIMMER TESTING WITH: LEDMODULE-S**

DATE: 15.7.20

DIMMER BRAND	DIMMER MODEL	PASS/FAIL	MAX LUX WITH NO DIMMER IN CIRCUIT	MAX LUX LEVEL WITH DIMMER IN CIRCUIT 100%	MIN LUX WITH DIMMER	% WHEN DIMMER ON MINIMUM SETTING	COMMENTS
HPM LEGRAND	EM400A2P	FAIL	518	62	8	13%	POOR RANGE
	EM400A3P	PASS	518	480	2	0%	SMOOTH
	EM400TR	PASS	518	284	5	2%	SMOOTH
	EM700TR	FAIL	518	405	131	32%	UNSTABLE
	EM250TR	PASS	518	350	15	4%	SMOOTH
PDL	PDL354PDBMBW	PASS	518	514	0	0%	SMOOTH
	PDL354PDBMUN	PASS	518	323	50	15%	SMOOTH
	PDL354RDMLED	PASS	518	319	5	2%	SMOOTH
	PDL624M	PASS	518	304	5	2%	SMOOTH
	PDL654M	PASS	518	343	5	1%	SMOOTH
KIWI	K005U	PASS	518	435	29	7%	SMOOTH
GERRARD	MEDM	PASS	518	362	8	2%	SMOOTH