

**DIMMER TESTING WITH: SLIMB180**

DATE: 17.3.20

DIMMER BRAND	DIMMER MODEL	PASS/FAIL	MAX LUX WITH NO DIMMER IN CIRCUIT	MAX LUX LEVEL WITH DIMMER IN CIRCUIT 100%	MIN LUX WITH DIMMER	% WHEN DIMMER ON MINIMUM SETTING	COMMENTS
HPM LEGRAND	EM400A2P	FAIL	81	48	1	2%	UNSTABLE
	EM400A3P	PASS	81	78	1	1%	SMOOTH
	EM400TR	PASS	81	67	1	1%	SMOOTH
	EM700TR	PASS	81	70	1	1%	SMOOTH
	EM250TR	PASS	81	67	1	1%	SMOOTH
PDL	PDL354PBDMBW	FAIL	81	74	1	1%	UNSTABLE
	PDL354PBDMUN	FAIL	81	0	0		UNSTABLE
	PDL354RDMLLED	PASS	81	70	1	1%	SMOOTH
	PDL624M	PASS	81	65	1	2%	SMOOTH
	PDL654M	PASS	81	68	9	13%	SMOOTH
KIWI	K005U	PASS	81	64	1	2%	SMOOTH
GERRARD	MEDM	PASS	81	70	1	1%	SMOOTH

**DIMMER TESTING WITH: SLIMB330**

DATE: 17.3.20

DIMMER BRAND	DIMMER MODEL	PASS/FAIL	MAX LUX WITH NO DIMMER IN CIRCUIT	MAX LUX LEVEL WITH DIMMER IN CIRCUIT 100%	MIN LUX WITH DIMMER	% WHEN DIMMER ON MINIMUM SETTING	COMMENTS
HPM LEGRAND	EM400A2P	FAIL	192	155		0%	UNSTABLE
	EM400A3P	PASS	192	192	22	11%	SMOOTH
	EM400TR	PASS	192	192	22	11%	SMOOTH
	EM700TR	PASS	192	192	33	17%	SMOOTH. ONLY DIMS TO 17%
	EM250TR	PASS	192	192	18	9%	SMOOTH
PDL	PDL354PBDMBW	PASS	192	192	1	1%	SMOOTH
	PDL354PBDMUN	PASS	192	192	1	1%	SMOOTH
	PDL354RDMLLED	PASS	192	192	2	1%	SMOOTH
	PDL624M	PASS	192	192	1	1%	SMOOTH
	PDL654M	PASS	192	192	47	24%	SMOOTH. ONLY DIMS TO 24%
KIWI	K005U	PASS	192	192	1	1%	SMOOTH
GERRARD	MEDM	PASS	192	192	1	1%	SMOOTH