

NXCFRD

Radiation Damper Instructions



1. Make electrical connections per fan instructions.
2. Install motor plate onto the housing.
3. Locate the housing on top of the damper as shown and secure with the (4) screws provided. The housing can be installed in one of two positions on the damper: as shown, or rotated 180°.
4. Install the radiation damper per local code requirements.
Note: The opening edge of the damper should be flush or slightly above the ceiling surface.
5. Install the grille and grille springs provided with the radiation damper using tabs shown for the grille springs.