Exova Warringtonfire Holmesfield Road Warrington WA1 2DS United Kingdom T : +44 (0) 1925 655 116 F : +44 (0) 1925 655 419 E : warrington@exova.com W: www.exova.com

Testing. Advising. Assuring.



Title:

CLASSIFICATION OF REACTION TO FIRE PERFORMANCE IN ACCORDANCE WITH EN 13501-1:2007+A1: 2009.

Notified Body No:

0833

Product Name:

"Digital Print 1.1 Fabric Backed Vinyl N/W"

Report No:

198243

Issue No:

1

Prepared for:

Muraspec, Tonbridge Road, East Peckham, Tonbridge, Kent, TN12 5JX

Date:

24th January 2011

1. Introduction

This classification report defines the classification assigned to "Digital Print 1.1 Fabric Backed Vinyl N/W", a family of digitally printed fabric backed vinyl wallcoverings, in line with the procedures given in EN 13501-1:2007+A1: 2009.

2. Details of classified product

2.1 General

The products, "Digital Print 1.1 Fabric Backed Vinyl N/W", a family of digitally printed fabric backed vinyl wallcoverings, are defined as being suitable for construction applications, excluding flooring and linear pipe thermal insulation.

2.2 Product description

The products, "Digital Print 1.1 Fabric Backed Vinyl N/W", a family of digitally printed fabric backed vinyl wallcoverings, are fully described below and in the test reports provided in support of classification listed in Clause 3.1.

| General description | Digitally printed fabric backed vinyl wallcoverings bonded to the primed face of a fibre cement board substrate |
|---|---|
| Product reference of wallcovering | "Digital Print 1.1 Fabric Backed Vinyl N/W" |
| Overall wallcovering thickness | 0.4mm (stated by sponsor) 0.35mm(determined by Exova Warringtonfire) |
| Overall wallcovering weight per unit area | 300g/m ² (stated by sponsor) 293g/m ² (determined by Exova Warringtonfire) |
| Range reference of wallcovering | "Digimura" |
| Colour / pattern | Any colour / pattern |

Continued on next page

| | Coating | Product reference | See note 1 | | |
|--|---------|-------------------------|----------------------------------|--|--|
| | | Generic type | PVC | | |
| | | Name of manufacturer | Muraspec | | |
| | | Application rate | See note 1 | | |
| | | Application method | See note 1 | | |
| | | Curing process | See note 1 | | |
| | | Flame retardant details | See note 1 | | |
| β | | Product reference | See note 1 | | |
| Wall covering | | Generic type | See note 1 | | |
| NOC | Fasing | Name of manufacturer | See note 1 | | |
| all c | Facing | Thickness | See note 1 | | |
| Ŵ | | Weight per unit area | See note 1 | | |
| | | Flame retardant details | See note 2 | | |
| | | Product reference | See note 1 | | |
| | | Generic type | Non woven polyester | | |
| | Dooking | Name of manufacturer | See note 1 | | |
| | Backing | Thickness | See note 1 | | |
| | | Weight per unit area | See note 1 | | |
| | | Flame retardant details | See note 2 | | |
| | | Product reference | "Murabond Heavy" | | |
| | | Generic type | See note 1 | | |
| ۸db | esive | Name of manufacturer | See note 1 | | |
| Aun | esive | Application rate | 200g/m ² | | |
| | | Application method | Roller / Brush | | |
| | | Flame retardant details | See note 3 | | |
| | | Product reference | "Murabond PVA Primer" | | |
| | | Generic type | Poly vinyl acetate (PVA) | | |
| Prim | or | Name of manufacturer | See note 1 | | |
| FIIII | IEI | Application rate | 25g/m ² | | |
| | | Application method | Roller | | |
| | | Flame retardant details | See note 3 | | |
| Substrate | | Product reference | "NT D4 604" | | |
| | | Generic type | Fibre cement board | | |
| | | Name of manufacturer | Scheerders van de Kerkhove (SVK) | | |
| | | Thickness | 8mm | | |
| | | Density | 1800kg/m ³ | | |
| Brief description of manufacturing process of wallcovering | | | See note 1 | | |

- Note 1 The sponsor of the test has provided this information but at the specific request of the sponsor, these details have been omitted from the report and are instead held on the confidential file relating to this investigation.
- Note 2 The sponsor of the test has confirmed that no flame retardant additives were utilised in the production of the product / component.
- Note 3 The sponsor was unable to provide this information.

3. Test reports/extended application reports & test results in support of classification

3.1 Test reports/extended application reports

| Name of Laboratory | Name of sponsor | Test reports/extended application report Nos. | Test method / extended application rules & date |
|----------------------------------|-----------------|---|---|
| Exova warringtonfire | Muraspec | WF 198150 | EN ISO 11925-2 |
| Exova warringtonfire | Muraspec | WF 198148, 195810, 195813 | EN 13823 |
| Exova warringtonfire Muraspec | | WF 198242 | EN/TS 15117 |

Page 5 of 7

3.2 Test results

| Test method & test number | | | | Results | | |
|---------------------------------|------------------------------|-----------------------------------|---------------------|---------------------------------------|--------------------------|--|
| | | Parameter | No. tests | Continuous parameter - mean (m) | Compliance parameters | |
| EN ISO 11925-2 | 30s exposure - surface | Fs | | Nil | Compliant | |
| | | Flaming droplets/ particles | 6 | None | Compliant | |
| | 30s exposure – edge | Fs | | Nil | Compliant | |
| | | Flaming droplets/ particles | 6 | None | Compliant | |
| | | | Formal test average | 13.31 | Compliant | |
| | | FIGRA 0.2MJ | Indicative 1 | 7.48 | | |
| | | | Indicative 2 | 7.54 | | |
| | | | Formal test average | 10.39 | | |
| | | FIGRA 0.4MJ | Indicative 1 | 7.48 | Compliant | |
| | | | Indicative 2 | 7.54 | | |
| | | | Formal test average | 1.66 | | |
| | | THR 600s | Indicative 1 | 1.23 | Compliant | |
| ΙE | N 13823 | | Indicative 2 | 1.28 | | |
| - | | | Formal test average | None | | |
| | | LFS | Indicative 1 | None | Compliant | |
| | | | Indicative 2 | None | | |
| | | 010000 | Formal test average | 6.38 | | |
| | | SMOGRA | Indicative 1 | 9.53 | Compliant | |
| | | | Indicative 2 | 6.24 | | |
| | | тер | Formal test average | 67.39 | Compliant | |
| | | TSP _{600s} | Indicative 1 | 87.52 | Compliant | |
| | | | Indicative 2 | 72.25 | <u> </u> | |

4. Classification and field of application

4.1 Reference of classification

This classification has been carried out in accordance with clause 8 of EN 13501-1:2007+A1: 2009.

4.2 Classification

The products, "Digital Print 1.1 Fabric Backed Vinyl N/W", a family of digitally printed fabric backed vinyl wallcoverings, in relation to their reaction to fire behaviour are classified:

В

The additional classification in relation to smoke production is:

s2

The additional classification in relation to flaming droplets / particles is:

d0

The format of the reaction to fire classification for construction products excluding flooring and linear pipe thermal insulation is:

| Fire Behaviour | | Smoke Production | | | Flaming Droplets | |
|----------------|---|------------------|---|---|------------------|---|
| В | - | s | 2 | ı | d | 0 |

i.e. B – s2 , d0

Reaction to fire classification: B – s2, d0

4.3 Field of application

This classification is valid for the following end use applications:

- Construction applications used over any substrate with a density equal to or greater than 1800Kg/m³, having a minimum thickness of 6mm and a fire performance of A2 or better.
- ii) Substrate prepared utilising 'Murabond PVA Primer', at an application rate of 25g/m².
- iii) Product installed utilising 'Murabond Heavy' adhesive, at an application rate of 200g/m².

This classification is also valid for the following product parameters:

| Product thickness | No variation allowed |
|------------------------------|-----------------------|
| Product weight per unit area | No variation allowed |
| Colour/Pattern | Any variation allowed |
| Adhesive | No variation allowed |
| Product construction | No variation allowed |

Page 7 of 7

5. Limitations

This classification document does not represent type approval or certification of the product.

SIGNED

APPROVED

mb) de

.....

Janes Nemel

Matthew Dale Certification Engineer Technical Department

Janet Murrell Technical Manager Technical Department on behalf of Exova warringtonfire

This copy has been produced from a .pdf format electronic file that has been provided by Exova Warringtonfire to the sponsor of the report and must only be reproduced in full. Extracts or abridgements of reports must not be published without permission of Exova Warringtonfire. The original signed paper version of this report is the sole authentic version. Only original paper versions of this report bear authentic signatures of the responsible Exova Warringtonfire staff.