



A P P R O V A L S ®

Certificate of Suitability

Addendum

Certificate No.: SAA160334

Date of Issue: 4 July 2016

Class Description: Non-Declared

Product Description: Bi-directional AC/DC Converter for use in a battery storage system

Additional Models

Multiplus 24/5000/120-100

Description

Similar to Multiplus 12/3000/120-16 except multiboard design and rated:
Input:-

AC: 187-250V~ 45-55Hz 50/50A

DC: 9.5-17Vdc 250A

Output:-

AC: 225-235V~ 50Hz 11A

DC: 13.2-14.1Vdc 120A

Quattro 12/3000/120-50/30

Similar to Multiplus 12/3000/120-16 except multiboard design and rated:
Input:-

AC: 187-250V~ 45-55Hz 50/30A

DC: 9.5-17Vdc 458A

Output:-

AC: 225-235V~ 50Hz 11A

DC: 13.2-14.1Vdc 120A

Quattro 12/3000/120-50/50

Similar to Multiplus 12/3000/120-16 except multiboard design and rated:
Input:-

AC: 187-250V~ 45-55Hz 50/50A

DC: 9.5-17Vdc 250A

Output:-

AC: 225-235V~ 50Hz 11A

DC: 13.2-14.1Vdc 120A


For and on Behalf of
SAA Approvals Pty Ltd

SAA Approvals Pty Ltd as accredited by JAS-ANZ under ISO/IEC 17065 certifies in accordance with the SAA Approvals Electrical Product Safety Certification Scheme that the product nominated in this certificate complies with standard/s listed.

When using the RCM the requirements of all relevant parts of AS/NZS 4417 applicable to the article must be fulfilled.

For SAA Contact Details and to verify this Certificate go to:
www.saaapprovals.com.au

JAS-ANZ



www.jas-anz.org/register



Issued: 04-07-16 160334/3